

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No. F.6/DFS/MS/School/2015/ 52/953

Dated: 9/6/15

**FIRE SAFETY CERTIFICATE**

Certified that the **Tagore Public School** located at D Block, Naraina Vihar, New Delhi-110028 is comprised of ground floor plus two upper floors was issued NOC by this department vide letter No.F.6/DFS/MS/School/2012/1734 dated 14.05.2012. The School building was re-inspected by the officer concerned of this department on 28.05.2015 in the presence of Sh. Vikas Bhatia (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on..... 9/6/15 ..... at New Delhi.

(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Principal,  
Tagore Public School, D Block,  
Naraina Vihar, New Delhi-110028.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110 054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N17

Ground floor plus two upper floors.

## INSPECTION REPORT

1. Name & address of the building: Tagore Public School, D-Block, Naraina Vihar,  
 2. Type of Occupancy: Educational (School) M.D.-28.  
 3. Type of Case: New Case/Renewal  
 4. Details of Previous NOC: Letter No. F.6/DFS/MS/School/2012/1734 Date 14.05.2012  
 5. Fire Safety directives letter No.: —  
 6. Date of inspection: 28.05.2015  
 7. Name of Inspecting Officer: A.D.O P.S. Dahiya  
 8. Name and designation of officers:  
 From the building side: Sh. Vikash Bhatia (Manager)  
 9. Year of Construction: 1982-83, 1995  
 10. Applicant's letter No.: Nil dated Nil

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	07 mtr	MR
	• Gate width	—	05 mtr	MR
	• Width of internal road	—	—	—
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	One	One	MR
	• Basements	—	—	No Basement
b.	Width of staircases			
	• Upper Floor	150 cms	158 cms	MR
	• Basements	—	—	No Basement
c.	Protection of exits			
	• Fire check door	—	—	—
	• pressurization	—	—	—
d.	No. of continuous staircases to terrace	—	—	—
e.	Width of Corridor	—	One	—
f.	Door Size	—	230 cms	—
		—	90 cms x 204 cms	—
3.	Compartmentation			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	Sealed	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System			
	• Basements	30 a/c per hour	—	No Basement
	• Upper floors		Natural Ventilation	MR





M19.

D-Block, Naraina Vihar,  
New Delhi - 110028.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	-	-	-
		450LPM	450LPM	MR
		30M	38M	MR
		-	-	-
		-	-	-
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	-	-
		10000 Ctr	10000 Ctr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts:</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	No Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
<b>17.</b>	<b>Standby power supply</b>	-	-	-
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-	-	-
		-	-	-
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-	-	-

N/10.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DRS/MS/School/2012/1734 dated 14.05.2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

  
Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

