

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax: 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333

No. *F6/DFS/MS/School/2015/52/1001*

Dated: *12/06/15*


FIRE SAFETY CERTIFICATE

Certified that **The Indian School located at Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049** was granted N.O.C. by this department vide letter No. F6/DFS/MS/2012/891 dated 12/03/2012 for ground and three upper floors. The building was re-inspected by the officer concerned of this department on 27.05.2015 in presence of Mr. K.S. Vaid, Bursar of the school and found that the school building has deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. 262-362 dated 17-01-2005 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on *12/06/15* at New Delhi by.



(Dr. G.C. MISRA)
CHIEF FIRE OFFICER

9c 

Copy to: -

1. The Principal, The Indian School Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049.
2. The Directorate of Education, Old Secretariat, NewDelhi-110006.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : The Indian School Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049
- 2 Type of Occupancy : Educational
- 3 Type of Case : Renewal
- 4 Details of previous NOC : F6/DFS/MS/2012/891 dated 12/03/2012
1. Fire Safety directives letter No : 262-362 dated 17-01-2005
- 5 Date of inspection : 27.05.2015
- 6 Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
- 7 Name and designation of officers from the building side : Mr. K.S. Vaid, Bursar
9. Year of Construction : 2009-10
10. Applicant's letter No. : Nil dated 13.04.2015.

The Indian School is comprised of ground and three upper floors.

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|--------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | Required | Provided | MR |
| | • Gate width | 4.5 mts | Provided | MR |
| | • Width of internal road | Required | Provided (06 mts.) | MR |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | ----- | ----- | ----- |
| | • Upper Floors | 03 | Provided | MR |
| | • Basements | N/A | N/A | N/A |
| | b. Width of staircases | ----- | ----- | ----- |
| | • Upper Floors | 1.5 mts each | Provided | MR |
| | • Basements | N/A | N/A | N/A |
| | c. Protection of exits | ----- | ----- | ----- |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | e. No. of continuous staircases to terrace | 01 | 01 | MR |
| | g. Width of Corridor | 1.5 mts | Provided | MR |
| | h. Door Size | 1.0 mts | Provided | MR |
| 3 | Compartmentation. | | | |

6

| | | | | |
|----|---|--|----------------------------------|---------------------------------|
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | 30 a/c per hour | N/A | N/A |
| | | 12 a/c per hour | N/A | N/A |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | 26 nos. ABC, CO ₂ type ISI marked | Provided Provided Provided | MR MR MR |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | 02 30 m 5 mm | Provided Provided Provided | MR MR MR |
| 7 | Automatic fire detection and alarming system Not required | | | |
| | <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> • Basement / Lower Ground • Upper Floor • Sprinkler above false ceiling | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor | 100 mm 02 | Provided Provided | MR MR |


| | | | | |
|----|--|-------------|--------------------|-------|
| | <ul style="list-style-type: none"> Hose Box | 02 | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | Required | Provided (06 nos.) | MR |
| | <ul style="list-style-type: none"> Hose Box | Required | Provided (06 nos.) | MR |
| 13 | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level | --- | ---- | ----- |
| | <ul style="list-style-type: none"> ➤ Discharge of main Pump | 900 LPM | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Head of Main pump | 48 mts | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Number of main pumps | 01 | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Jockey Pump out put | 180 LPM | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Jockey pump head | 35 mts. | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Standby Pump out put | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Standby Pump Head | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Pump House Access | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Terrace level | ---- | ----- | ----- |
| | <ul style="list-style-type: none"> ➤ Discharge of pump | 180 lpm | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Head of the pump | 30 mts | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Power Supply | Required | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity | 40,000 lts. | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Draw-off connection | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> ➤ Fire service inlet | Required | Provided | MR |
| | <ul style="list-style-type: none"> ➤ Access to tank | Required | Provided | MR |
| | <ul style="list-style-type: none"> Overhead Tank capacity | 15,000 lts | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. Not Applicable | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Pressurization of Lift lobby | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Communication In lift Car | N/A | N/A | N/A |

| | | | | |
|----|--|----------|--|-----|
| | <ul style="list-style-type: none"> • Fireman's Grounding Switch | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Flow Switch Panel | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • PA System Panel | Required | Provided | MR |
| | <ul style="list-style-type: none"> • Batter backup | Required | Provided | MR |
| | <ul style="list-style-type: none"> • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | Required | 02 ABC type fire extinguisher is provided near elect. Panel. | MR |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/2012/891 dated 12/03/2012, renewal under the Directorate of Education circular No. 262-362 dated 17/01/05 is recommended.

DFA is put up for approval & signature please



DO(SZ)

DCFO(SZ)

Signature of the Inspecting Officer
Name (M.K. CHATTOPADHYAY)
Designation: - Assistant Divisional Officer

[Handwritten Signature]
29/5/15

[Handwritten Signature]
11/6/15