

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/ 2015/W2/927

Dated: 05/06/2015

FIRE SAFETY CERTIFICATE

Certified that the **D.A.V. Centenary Public School**, at **Paschim Enclave, Rohtak Road, Delhi-87**, comprised of **Ground + Three Upper Floors** owned / occupied by **D.A.V. Centenary Public School**, has already been issued Fire Safety Certificate **Vide letter No. F6/MS/DFS/2007/1778 dated 05/07/2007**. The premises was re-inspected by the officer concerned of Fire Service on **06.05.2015** in the presence of **Manju Malik (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with **Directorate of Education, Circular No. 262-362 dated 17.01.2005** and that the building / premises is fit for occupancy class-B **Educational** with effect from 05/06/2015 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.
8. Fourth Floor shall not be used for any purpose and kept sealed all the time as found during inspection and the undertaking given by management vide their letter No. DAV/MN/PR/2015-16/053 dated 27/4/2015.

Issued on 05/06/2015 at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
Phone :23414250

Copy to :-

1. The Principal, D.A.V. Centenary Public School, Paschim Enclave, Rohtak Road, Delhi-110087.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.



INSPECTION REPORT

1. Name & address of the building: **DAV Centenary Public School, Paschim Vihar, Rohtak Road, New Delhi-110087.**
2. Type of Occupancy : **Educational (G+3 Upper Floors)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **Letter No. F6/DFS/MS/2007/1778 dated 05/7/2007**
5. Fire Safety directives Letter No. : **D.O.E. Circular 262-362 dated 17.01.2005**
6. Date of inspection : **06/05/2015**
7. Name of the Inspecting Officer : **Ashok Kumar Jaiswal (A.D.O. Jwala Puri)**
8. Name and designation of Officer
from the building side : **Manju Malik (Principal)**
9. Year of Construction : **2006**

10. Applicant's letter No. : DAV/MN/PE/2015-16/053 dated 27/04/2015


S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. 2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	1 (Stair) 1 (Ramp)	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50 mtr	1.20 (Stair) 1.20 (Ramp)	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	b. No of continuous staircase to terrace	1	Provided	MR
	c. Width Of Corridor	1.50 mtr	Provided	MR
	d. Door Size	1.00 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	14	14	MR
	• Type	ABC /Co	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater	NR	NR	NR
	• Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NR	NR	NR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 LPM & 180 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank	NR	NP	NR

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Batter backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2007/1778 dated 05/7/2007** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 6/5/2015

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

D.O. (W)