

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

No.F.6/DFS/MS/School/2015/52/1030

Fax: - 011-23412593

Dated: 18/06/15

FIRE SAFETY CERTIFICATE

Certified that the building of **Govt. Girls Sr. Sec. School, Khaira, New Delhi 110043** is having two blocks namely Block-A and Block-B, Block-A is comprised of ground floor and Block-B is Comprised of ground plus one upper floor only. Block-A was issued Fire Safety Certificate by this department vide letter F6/DFS/MS/2011/School/3587 dated 16.12.2011. The School building was re- inspected by the officer concerned of this department on 01.06.2015 in the presence of Smt. Manju Rani (Vice-Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....18/06/15..... at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
Govt. Girls Sr. Sec. School,
Khaira, New Delhi 110043.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054.

O/C San
17/6/15

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

School is comprised of two blocks namely Block-A & Block-B, Block-A is comprised of Ground Floor only and Block-B is comprised of Ground plus one upper floor Only.
(Govt. Girls Sr. Sec. School, Khaira, New Delhi 110043)

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Sec. School, Khaira, New Delhi 110043.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/2011/School/3587 dated 16.12.2011
5. Fire Safety directives letter No : N/A
6. Date of inspection : 01.06.2015
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Smt. Manju Rani (Vice-Principal)
9. Year of Construction : 1986 onward
10. Applicant's letter No. : Letter No. 75 dated 15.05.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>08 mtrs</p> <p>4.2 & 2.9 mtrs.</p> <p>—</p>	<p>M/R</p> <p>—</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>.02 No.'s</p> <p>N/A</p>	<p>02 No.'s Block-B</p> <p>N/A</p>	<p>M/R</p> <p>No basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>1.5 mtrs.</p> <p>N/A</p>	<p>186 & 208 cms</p> <p>N/A</p>	<p>M/R</p> <p>No basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>
	d. No. of continuous staircases to terrace			
		<p>N/A</p> <p>1.5 mtrs.</p>	<p>N/A</p> <p>155 cms</p>	<p>N/A</p> <p>M/R</p>
	e. Width of Corridor			
	f. Door Size			
		<p>—</p>	<p>98 cms (2 no's each)</p>	<p>M/R being old case</p>
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	<p>N/A</p>	<p>N/A</p>	<p>No basement</p>

School is comprised of two blocks namely Block-A & Block-B, Block-A is comprised of Ground Floor only and Block-B is comprised of Ground plus one upper floor Only.
(Govt. Girls Sr. Sec. School, Khaira, New Delhi 110043)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			(No Lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N/S

School is comprised of two blocks namely Block-A & Block-B, Block-A is comprised of Ground Floor only and Block-B is comprised of Ground plus one upper floor Only.
(Govt. Girls Sr. Sec. School, Khaira, New Delhi 110043)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/2011/School/3587 dated 16.12.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Sandeep
03/6/15

Signature of Inspecting Officer

Name: - Sandeep Duggal

Designation: - Asstt. Divisional Officer

~~Signature of Inspecting Officer~~

~~Name~~

~~Designation~~

K. Kumar
5/6/15

Divisional Officer (South West)

