

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F6/MS/DFS/School/2015/ 52/1051

Dated: 19/06/15

FIRE SAFETY CERTIFICATE

Certified that Gyan Bharti School, located at Saket, New Delhi-110017 comprised of basement, ground and three upper floors owned/occupied by Gyan Bharti School Management was issued NOC vide letter no.F6/DFS/MS/School/2011/3561 dated 16/12/2011 by this department. The school building was re-inspected by the officer concerned of this department on 05/06/2015 in the presence of Mr. Ritesh Jain & Mr. B.B. Ahuja and found that the School building have deemed complied with the fire prevention and fire safety requirements and that the school building is fit for occupancy class "Educational" (School) with effect from the date of issue.. 19/06/15 of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on -----19/06/15----- at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Tel: 011-23414333

o/c *19/06/15*

Copy to: -

The Authorised Signatory,
Gyan Bharati School,
Saket, New Delhi-110017

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. The basement shall be used as per the provisions of BBL/NBC.
5. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Gyan Bharti School,Saket , New Delhi-110017
2. Type of Occupancy : Educational (School)
3. Type of Case :Renewal
4. Details of previous NOC : F6/DFS/MS/School/2011/3561 dated 16/12/2011
5. Fire Safety directives letter no. : Nil.
6. Date of inspection : 05/06/2015
7. Name of the Inspecting Officers : ADO D.B.Mukherjee
8. Name and designation of officers
from the building side : Mr. Ritesh Jain & Mr.B.B.Ahuja
9. Year of Construction : 1978
10. Applicant's letter No. :Nil dated:05/06/2015

The school is running in three blocks A block - Science block, B-block - Main block & C block is nursery block. A block has G + 3 upper floors, B block Basement,ground and 02 upper floors & C blocks has ground + one upper floor

(Old Case)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directorate of Education Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	13.50mtr	MR
	• Gate width	Required	6.88mtr	MR
	• Width of internal road	Required	6mtr	MR
2	Number, Width, Type & Arrangement of Exits			
a. Number of staircases				
	• Upper Floors	Required	A block 02nos,B block 02nos, C block 01nos + 1Ramp	MR
	• Basements	Required	B block Basement 01no +01 Ramp	MR
b. Width of staircases				
	• Upper Floors	Required	A block 1.47m,1.18mtr,B block 1.40m,1.30m,C block 1.10m & 1.04(ramp)	MR
	• Basements	Required	1.40mtr, 1.34mtr (Ramp)	MR
c. Protection of exits				
	• Fire check door	Required	Provided in the basement	MR
	• Pressurization	N/A	N/A	N/A
e. No. of continuous staircases to terrace				
		Required	02	MR
g. Width of Corridor				
		Required	230mtr,240mtr & 165 mtr	MR
h. Door Size				
		Required	1mtr	MR

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided in basement	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Exhaust Fan	MR
		12 a/c per hour	Exhaust Fan	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Required	40 nos.	MR
		ABC,CO ₂	Provided	MR
		Required	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA			
		N/A	N/A	N/A
9	Public Address System.			
		Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100mm	Provided	MR
		02	Provided 02no	MR
		02	Provided 02no	MR

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided 450lpm, 4 nos	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	Required	Provided 5,000ltr x5	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided D G Set	MR

2/11

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	Required	Provided	MR
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the school were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2011/3561 dated 16/12/2011, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature pl.

[Handwritten Signature]
15/6/15

Signature of the Inspecting Officer
Name: (D.B.Mukherjee)
Designation :- Assistant Divisional Officer

DO (Security) on leave

