

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F6/DFS(MS)2015/52/1027

Dated: 18/06/15

FIRE SAFETY CERTIFICATE

Certified that the M/S Narula Coal Company, Behind Pirthavi Raj Market, P.R.Lane, (Back Side), Near Khan Market, New Delhi-110003, comprised of one room ground floor only for office purpose and coal & wood depot in open, owned/occupied by M/S Narula Coal Company was granted No Objection Certificate by this department vide letter No. F5/(12)/DFS/2006/466, dated 18-12-2006. The premises was re-inspected by the officer concerned of this department on 10-06-2015 in the presence of Sh. Satish Narula Owner and found that the said Coal & Wood Depot have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, and found that the said Coal & Wood Depot premises is fit for occupancy class Storage (Coal & Wood Depot) with effect from 18/06/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...18/06/... 2015 at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
T.No.011-23414333

Copy to:-1. Dr.P.K.Sharma, Medical Officer of Health & Licencing Authority, NDMC, New Delhi.
2. M/S Narula Coal Company, Behind Pirthavi Raj Market, P.R.Lane, New Delhi.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S Narula Coal Company, Behind Pirthavi Raj Market, P.R.Lane, (Back Side), Near Khan Market, New Delhi-110003.
2. Building is comprised of : One Room Ground Floor only for office. Coal and wood depot in open.
3. Type of Occupancy : Storage (Coal and Wood Godown in open area app. 200sq. meters).
4. Type of Case : Renewal
5. Details of Previous NOC : No.F5/(12)/DFS/2006/466, Dated 18.12.2006.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 10.06.2015
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of officer from the building side : Sh. Satish Kumar Narula (Owner).
10. Year of Construction :2003.
11. Applicant's letter No. : No.MOH/518/C.S.I.(Lic)/D/SI-VI, dated 21.04.15.


S.N	Minimum Standards on fire prevention and fire safety U/R33	Requirements	Provided at Site	Remarks	
1	Access to building				
	Road width	6m	6m	MR	
	Gate width	N.A.	N.A.	N.A.	
	Width of internal road	N.A.	N.A.	N.A.	
2	Number, Width, Type and Arrangement of Exits.				
	a. Number of Staircases	N.A.	N.A.	N.A.	
	Upper Floor	N.A.	N.A.	N.A.	
	Basement	N.A.	N.A.	N.A.	
	B. Width of Staircases	N.A.	N.A.	N.A.	
	Upper Floor	N.A.	N.A.	N.A.	
	Basement	N.A.	N.A.	N.A.	
	c. Protection of exits	N.A.	N.A.	N.A.	
	Fire check door	N.A.	N.A.	N.A.	
	Pressurization	N.A.	N.A.	N.A.	
	e. No. of continuous staircases to terrace.	N.A.	N.A.	N.A.	
		N.A.	N.A.	N.A.	
	g. Width of Corridor	1m	1m	MR	
h. Door Size					
3	Compartmentation				
	Fire check door	N.A.	N.A.	N.A.	
	Sealing of electrical shafts	N.A.	N.A.	N.A.	
	Fire rating of shaft door	N.A.	N.A.	N.A.	
	Water curtain	N.A.	N.A.	N.A.	
	Fire Dampers	N.A.	N.A.	N.A.	
4	Smoke Management System.				
	Basement	30a/c per hour	N.A.	N.A.	
	Upper floor	12a/c per hour	N.A.	N.A.	
5.	Fire Extinguisher				
	Total numbers	02 nos.	02 nos.+1drum water(200L)+4nos Sand Buckets		MR
	types	WCO ₂	WCO ₂ + Water Drum		MR
	IS marking	ISI marked	ISI marked		MR
6	First-aid-Hose Reels.				
	Total numbers of each floor	N.A.	N.A.	N.A.	
	Length of hose reel hose	N.A.	N.A.	N.A.	
	Nozzle diameter	N.A.	N.A.	N.A.	

7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA			
9	Public address System.			
10	Automatic Sprinkler System.			
	Basement/Lower ground floor	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.

17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	1.No electric Connection/point. 2. No smoking Sign boards	1.No electric connection Or point in go down area. 2. No smoking sign Boards provided.	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.5/(12)/DFS/2006/466, dated 18.12.2006 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration please.



D.O. (South)

[Handwritten signature]
17/6/15

[Handwritten signature] 11/6/15

Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO