

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. AG/DFS/MS/2015/WZ/1025

Dated: 18/06/2015

**FIRE SAFETY CERTIFICATE**

Certified that the M/S N. V. Cos, O-66, Sector-2, DSIDC Bawana Delhi-110039 located on Ground & first floor of a premises comprised of Basement + Ground + One upper floor owned/occupied by M/S N. V. Cos has already been issued FSC / NOC by this department to M/s Sapna Herbals & Cosmetics Pvt. Ltd. Vide letter No.F-5/(3A)/DFS/2009/52 dated 16/01/2009. The premise was re-inspected by the officer concerned of this department on 22/05/2015 in the presence of Sh. Rajesh Jain (Manager) of the factory and found that the building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the Fire Safety Certificate is renewed and a premise is fit for Class-G-2 (ii) Industrial with effect from 18/06/2015 for a period of three years subject to

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 18/06/15 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:-**

1. M/S N. V. Cos, O-66, Sector-2, DSIDC Bawana Delhi-110039
2. The Assistant Drugs Controller & Licensing Authority, Govt. of NCT of Delhi, F-17, Karkardooma, New Delhi-110032

**INSPECTION REPORT**

Basement – Lying vacant  
Gr floor - Nail Polish Manufacturing  
1<sup>st</sup> floor- -do-

1. Name & address of the building : N V Cos O-66, Sectir-2 DSIDC, Bawana Delhi-110039
2. Type of Occupancy : Industrial G-2(ii)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.5/(3A)/DFS/09/52 Dated: 16/01/2009
5. Fire Safety directives letter No : NCB Part IV
6. Date of inspection : 22/05/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers  
from the building side : Sh. Rajesh Jain (Manager)
9. Year of Construction : 2008
10. Applicant's letter No. : F.NW-33/Cos/14/855 dated 21/01/2015

Plot Area:100 sq m Covered Area:280 sq m

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	01	01	MR
	• Basements	NA	02	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floors	Old Case	Old Case	Old Case
	• Basements	NA	85 & 110 cms	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	R	P	MR
	g. Width of Corridor	NA	NA	NA
	h. Door Size	1.00 mtr	2.10 & 1.05 mtr	MR

N-4

3	<b>Compartmentation.</b>	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Exhaust provided	MR
	• Upper floors	12 a/c per hour	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	9ABC	9	M/R
	• Types	ISI marked	ABC	M/R
	• IS marking		Yes	M/R
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	One	P	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5 mm	P	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	R	P	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	450 LMP	P	MR
	➤ Head of the pump	40 m	P	MR
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	P	MR
15	<b>Exit Signage.</b>	R	P	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA

18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F.5/(3A)/DFS/09/52. dated 16/01/2009 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*[Handwritten Signature]*  
28/5/15  
AOO (E)

