

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593


No. F.6/DFS/MS/GH/2015/ 52/1056

Dated: 19/06/15

**FIRE SAFETY CERTIFICATE**

Certified that the **Hotel M.S. Regency** located at 15A/23, WEA, Karol Bagh, New Delhi-110005 is comprised of Basement, Ground Floor plus four upper floors, using basement as hall/storage, ground floor as reception & office, first, second & third floor each having 08 guest rooms respectively (Total 24 guest rooms) and a pantry for staff on fourth floor was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2012/1885 dated 24.05.2012 owned/ occupied by Sh. Ankur Madan. The guest house building was re- inspected by the officers concerned of this department on 09.06.2015 in the presence of Sh. Manoj Upadhyay (Manager) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....19/06/15.....at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:-011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.)  
1<sup>st</sup> floor, P.S., Defence Colony, New Delhi.  
(Re. No.528/Joint C.P./Lic.(H), Dated 01.06.2015)
2. Sh. Ankur Madan (Owner)  
Hotel M.S. Regency, 15A/23,  
WEA, Karol Bagh, N.D-05.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/13

Basement, Ground Floor plus four upper floors.

## INSPECTION REPORT

1. Name & address of the building : Hotel M.S. Regency, 15A/23, WEA, Kosa Bagh,  
 2. Type of Occupancy : Residential (Guest House) N.D.-05.  
 3. Type of Case : New Case/Renewal  
 4. Details of Previous NOC : Letter No. F.6/DFS/MS/GH/2012/1885 Date 24.05.2012  
 5. Fire Safety directives letter No :  
 6. Date of inspection : 09.06.2015  
 7. Name of Inspecting Officer : D.O.S.K. Tomar & A.D.O P.S. Dahiya  
 8. Name and designation of officers :  
 From the building side : Sh. Manoj Upadhyay (Manager)  
 9. Year of Construction : Before 2005  
 10. Applicant's letter No. : 528/Joint C.P/Lic. (H) dated 01.06.2015


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	06 mtr	MR
	• Gate width	-	150 cms	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	One	One	MR
	• Basements	-do-	-do-	MR
b.	Width of staircases			
	• Upper Floor	-	130 cms	MR, Old Case
	• Basements	-	121 cms	-do-
c.	Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
d.	No. of continuous staircases to terrace			
		-	One	-
e.	Width of Corridor			
		-	120 cms, 230 cms	-
f.	Door Size			
		-	87 cms x 205 cms	-
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements			
	• Upper floors	30 a/c per hour	Exhaust Fans are Provided Natural Ventilation	MR MR

		12 a/c per hour	-	-
5.	<b>Fire Extinguishers</b>			
	• Total numbers	Two at each floor	Provided	MR
	• Types	CO <sub>2</sub> , ABC, HCO <sub>2</sub>	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	<b>MOEFA</b>			
		Required	Provided	MR
9.	<b>Public Address System</b>			
		- do -	- do -	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
		-	-	-

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	-	-	-
		-	450 LPM	MR, Old Case
		Required	30 M Provided	MR, Old Case MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	-	-	-
		-	Provided	MR
		-	6000 Ltr	MR, Old Case
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts:</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	-
		-	Provided	MR
		Required	- do -	MR
		- do -	- do -	MR
<b>17.</b>	<b>Standby power supply</b>	Required	D.G. Set of 125 KVA	MR
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-	-	-
		-	-	-
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	-	-	-
		-	Provided	MR
		-	-	-
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-	-	-

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2012/1885 dated 24.05.2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



  
12/11/15

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer

  
11/11/15

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer