

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. FG/DFS/MS/BNST/2015/W2/1017

Dated: 17/06/15

FIRE SAFETY CERTIFICATE

Certified that the Golden Crown Banquet (A unit of M/s Masala Magic Hospitality Pvt. Ltd.) located at Ground Floor, 36, Rama Road Industrial Area, New Delhi - 110015 in a building comprised of Basement + Ground + 1 Upper Floor owned/ occupied by Golden Crown Banquet (A unit of M/s Masala Magic Hospitality Pvt. Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 01-05-2015 in the presence of Mr. Sunil Arora (Director) and found that the said building that the premises is fit for occupancy class "Assembly" Group D ^{at G-F} with effect from 17/06/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/06/15 at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Tel.No. - 23414250

Copy to:

1. Sh. Sunil Arora (Director),
Golden Crown Banquet (A unit of M/s Masala Magic Hospitality Pvt. Ltd.),
Ground Floor, 36, Rama Road Industrial Area, New Delhi - 110015.
2. Dy. Health Officer, Karol Bagh Zone,
NDMC, Public Health Department, Karol Bagh, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The means of escape shall not be kept locked and remain unobstructed for free movement of occupants in case of an emergency.
7. The FSC is valid only for G.F. to M/s Golden Crown Banquet only.
8. Basement shall be used strictly as per Building Bye Laws.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
10. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Golden Crown Banquet (A unit of M/s Masala Magic Hospitality Pvt. Ltd.), Ground Floor, 36, Rama Road Industrial Area, New Delhi – 110015.
2. Type of Occupancy : Assembly (Basement + Ground + 1 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 01-05-2015
7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Sunil Arora (Director)
9. Year of Construction : 2014
10. Applicant's letter No. : DHO/KBZ/2015/2783 dated 11-03-2015

Basement – Storage (Area=820 m²)
 Ground – Banquet (Area=820 m²)
 First – Banquet namely Radha Palace ✓


S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided ✓	MR
	• Gate width	4.5 m	On Main Road ✓	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X2m	2X2m, 159 cm, 94 cm ✓	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NR	NP	NR
	• Fire Rating of shaft door	NR	NP	NR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

.....

Signature of the Inspecting Officer
Name
Designation

MUKESH VERMA
A.P.O. 10

Signature of the Inspecting Officer
Name
Designation