

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/GH/2015/W2/1173

Dated: 03/07/15

FIRE SAFETY CERTIFICATE

Certified that the **Aman Deluxe** located at **A - 31, Vishal Enclave, Rajouri Garden, New Delhi** comprised of Basement + Ground + 3 Upper Floor was issued FSC vide letter no. F6/DFS/MS/GH/2012/2085 dated 07-06-2012. The premises was re inspected by the officers concerned of this department on 19-06-2015 in the presence of Mr. Baldev Singh (Proprietor) and found that the said guest house is presently running on F.F and S.F., having 14 Guest Rooms. The premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Residential Building" Group A of Sub Division - A 1 with effect from 03/07/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/07/15 at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Ph.011-23414250

Copy to:

1. Sh. Baldev Singh, Aman Deluxe, A - 31, Vishal Enclave, Rajouri Garden, New Delhi.
2. The Joint Commissioner of Police (Lic.), Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per BBL.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Aman Dx Guest House, A-31, Vishal Enclave, Rajouri Garden, New Delhi.
2. Type of Occupancy : Residential (Guest House) (Basement + Ground + 3 Upper Floor, Guest House at FF & SF with 14 Guest Rooms)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2012/2085 Dated 07-06-2012
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 19-06-2015
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Mr. Baldev Singh
9. Year of Construction : 1991
10. Applicant's letter No. : 514 /Joint C.P./Lic. (H) dated 01-06-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtrs	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	Required	Provided	MR
	f. Door Size	1 mtrs	Provided (with door frame)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft	NA	NA	NA

	door			
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.	12	MR
	• Types	ABC & CO ₂	ABC & Co ₂ Typs	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	One	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	100 m	Provided	MR
	• Number of hydrants per floor	1	Provided in each floor	MR
	• Hose Box	1	Provided in each floor	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2012/2085 Dated 07-06-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Mukesh Verma

Name

Designation

AD (MN)

Designation

