

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F.6/MS/DFS/2005/N102/1124

Dated: 30/06/15

FIRE SAFETY CERTIFICATE

Certified that the Bhai Parmanand Vidya Mandir at Surya Niketan, Anand Vihar, Delhi-92, owned/occupied by Bhai Parmanand Vidya Mandir, comprised of (Two Block) ground plus three upper floors was granted NOC vide letter no.F.6/MS/DFS/2005/939 dated 04.05.2005. The School building was inspected by the officer concerned of this department on 20.06.15 in the presence of Sh.Parveen Kumar, Office -Incharge of school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of condition under rule 38 and that the GF+FS+SF+TF of building is fit for occupancy Group B "Educational Building" with effect from .....30/6/15..... for a period of three years, subject to conditions printed overleaf.

Issued on .....30/6/15..... at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

To,  
The Principal  
Bhai Parmanand Vidya Mandir  
Surya Niketan, Anand Vihar, Delhi-92

Copy to:-  
The Dy. Director of Education  
D-Block, Anand Vihar, Delhi.

Copy/1/2

## CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Bhai Parmanand Vidya Mandir at Surya Niketan,  
Anand Vihar, Delhi-92
2. Building is comprised of : Two Blocks G+3 upper floors
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC : F.6/MS/DFS/2005/939 Dated 04.05.2005
6. Fire Safety Circular No. : F6/MS/DFS/BP/2000/194 dated 02.02.2000
7. Date of Inspection : 20.06.2015
8. Name of the Inspecting officers : ADO Suresh Singh
9. Name and designation of  
Officer from the building side : Sh. Parveen Kumar (Office -Incharge).
10. Year of Construction : 2000
11. Applicant's letter No : Nil Dated 25.04.2015

NO.	Minimum Standards on fire prevention and fire safety U/R33	Directives Requirement	Provided at Site	Remark
1	Access to building			
	• Road width	06 Mtrs.	07 Mtrs.	MR
	• Gate width	4.5 M	2 No. 5 M	MR
	➤ Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	04 Nos.	4 Nos.	MR
	• A- Block G+3	02 Nos.	2 Nos.	MR
	➤ B- Block G+3	02 Nos.	2 Nos.	MR
	➤ Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.5 M	1.5 M	MR
	➤ A- Block G+3	1.5 M	1.5 M Each	MR
	➤ B- Block G+3	1.5 M	1.5 & 1.45 M	MR
	➤ Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 No.	04 Nos.	MR
	e. Width of Corridor	1.5 M	1.5 M	MR
	f. Door Size	1.0 Mtrs	1.0 M	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	45 Nos.	64 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	03 Nos.	03 Nos.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 MM	5 MM	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	3 No.of 100 MM	MR
	• Number of hydrants per floor	3 Nos.	3 Nos.	MR
	• Hose Box	3 Nos.	3 Nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	35,000 Ltrs.	35,000 Ltrs.	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as per letter no. F6/MS/DFS/BP/2000/194 dated 02.02.2000. The NOC issued vide letter F6/MS/DFS/2005/939 Dated 04.05.2005 is recommended for fire safety certificate.

*Suresh Singh*  
21.6.15

Signature of the Inspecting Officer  
Name: Suresh Singh  
Designation: ADO (Shah.)

DO (ED)