

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.

F6/DFS/MS/EH/2015/WZ/1125

Dated:

30/6/15

FIRE SAFETY CERTIFICATE

Certified that the **Game of Legend (A unit of M/s Apple International)** located at **TF – 02A, City Square Mall, Shivaji Palace, III Floor, Raja Garden, New Delhi – 110027** was issued FSC vide Letter No. F6/DFS/MS/EH/2011/2897 dated 08-11-2011. FSC issued to the mall has already been renewed by deptt vide letter no. F6/DFS/MS/2014/WZ/523 dated 28-04-2014. The premises was re inspected by the officers concerned of this department on 05-06-2015 in the presence of Mr. Ajit (Sr. Manager) and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D with effect from 30/6/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/6/15..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: - 011-23414250

Copy to:

1. The Authorised Signatory,
Game of Legend (A Unit of M/s Apple International),
TF-02 A, Third Floor, City Square Mall, Raja Garden, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Game of Legend (A Unit of M/s Apple International)
Located at TF-02 A, Third Floor, City Square Mall, Raja Garden, New Delhi.
2. Type of Occupancy : Class D(Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2011/2897 Date 08-11-2011
5. Fire Safety directives Letter No. : Nil (FSC issued to mall vide Letter No. F6/DFS/MS/2014/WZ/523 dated 28-04-2014.
6. Date of inspection : 05-06-2015
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Ajit (Sr. Manager)
9. Year of Construction : 2011
10. Applicant's letter No. : Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building(For Mall)			
	• Road width	09mtrs	30 mtr	MR
	• Gate width	6mtr	Provided	MR
	• Width of internal road	6 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits (For Mall)			
	a. Number of staircases			
	• Upper floors	3	3	In mall/MR
	• Basements	5	5	MR
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	3	3	MR
	e. Width Of Corridor	Required	Provided	MR
	f. Door Size	2 mtrs & 1.5 m	Provided	MR
3.	Compartmentation (For Mall)			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	4 hrs	Provided	MR
	• Water Curtain	NR	NR	MR
	• Fire Dampers	NR	NR	MR

4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	4 nos.	Provided	MR
	• Types	ABC, CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels (For Mall)			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30 m	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system (For Mall)			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Ground floor	Provided	MR
	• Alternate source of power	Required	2Generator 450 KVA each	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	150 mm	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	4	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements (For Mall)			
	• Ground Level			
	• Discharge of main pump	2850LPM	Provided	MR
	➤ Head of main pump	60mtr	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	60mtr	Provided	MR
	➤ Standby Pump out put	2850lpm	Provided	MR
	➤ Standby Pump Head	60 mtr	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	Common with the mall		
	➤ Discharge of pump	900 lpm	NP	MR for restaurant
	➤ Head of the pump	40 mtr	NP	MR for restaurant

	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting (for mall)			
	• Under ground tank capacity	1,00,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2011/2897 Date 08-11-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

Mukesh 8/16/15

MUKESH VERMA

ADO (M)