

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No.F6/DFS/MS/ 2015/w2/1163

Dated: 03/07/15

FIRE SAFETY CERTIFICATE

Certified that the **Kapo Footwears Pvt. Ltd.** at Plot No. H-36, Udyog Nagar Industrial Area, Rohtak Road, New Delhi-110041 comprised of basement, ground floor, Mezzanine floor and first floor only owned / occupied by Kapo Footwears Pvt. Ltd, has already been issued Fire Safety Certificate vide letter No.F6/DFS/MS/Indl./2011/3701 dated 26/12/2011. The premises / building was re-inspected by the officer concerned of Fire Service on 11/06/2015 in the presence of Sh. Ashwini Kapoor and found that building / premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Industrial Group (G)** with effect from - 03/07/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010,

Issued 03/07/15 at New Delhi by.

(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Ph- 011-23414250

Copy to:-

1. Sh. Ashwini Kapoor, Kapo Footwears Pvt. Ltd.
Plot no. H-36, Udyog Nagar Industrial Area, Rohtak Road,
New Delhi-110041

Conditions for the validity of fire safety certificate

1. All the fire safety arrangement provided their in shall be mentioned good working condition at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified concerned building sanctioning agency.
5. This basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularization of unauthorized construction.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. the form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

N/16

1. Name & address of the building: Kapo Footwears pvt. Ltd. Plot No. H-36, Udyog Nagar Industrial Area, Rohtak Road, New Delhi-41
2. Type of Occupancy : Industrial (Class-G)
3. Type of Case : Renewal **Basement + GF + Mezz.F + 1st Floor**
4. Details of previous NOC : No.F6/DFS/MS/Indl/2011/3701 dated 26.12.2011
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/86/114 dated 10.02.1986
6. Date of inspection : 11/06/2015
7. Name of the Inspecting Officer : A. K.-Jaiswal
8. Name and designation of Officer
from the building side : Sh. Ashwini Kapoor
9. Year of Construction : 1992-93
10. Applicant's letter No. : -Nil Dated 13/5/2015


S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	15 mtr.	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	3 mtr.	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.20	Provided	MR
	• Basements	1.20	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	As per sanctioned plan	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.00mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	0	15	15

6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	2	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30Mtr.	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm.	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	N/A		
	<ul style="list-style-type: none"> Discharge of main pump 	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 			
	➤ Discharge of pump	900Lit/min.	Provided	MR
	➤ Head of the pump	30 mtr.	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
			Provided	M/R

		Required	Provided	M/R
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Indl/2011/3701 dated 26.12.2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended..


11/6/15

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)