

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DPS/ms/school/2015/ND2/1156

Dated: 02/07/15

FIRE SAFETY CERTIFICATE

Certified that the Rishabh Public School at Pocket –IV, Mayur Vihar Phase-1, Delhi-91, comprised of (A-Block G+2 & B-Block B+G+3) basement, ground plus three upper floors owned/occupied by Rishabh Public School have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 26.05.2015 in the presence of Smt.Lata Singh (Principal) and found that the B+GF+FF+SF+TF of building is fit for occupancy class 'B' 'Educational Building' with effect from 02/07/15... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on..... 02/07/15 ..... at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

To,  
The Principal  
Rishabh Public School  
Mayur Vihar Phase -1, Delhi -91.

Copy to:-  
The Dy. Director of Education  
D-Block, Anand Vihar, Delhi.



## CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction if any.
6. Basement shall be used as per BBL.
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



1. Name & address of the building : Rishabh Public School at Pocket – IV,  
Mayur Vihar Phase -1, Delhi -91.
2. Building is comprised of : A-Block (G+2), B-Block (B+G+3).
3. Type of Occupancy : Educational
4. Type of Case : Addition/Alternation
5. Details of Previous FSC : F.6/DFS/MS/2011/1541 Dated  
08.07.2011
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398  
dated 1.3.11
7. Date of Inspection : 26.05.2015
8. Name of the Inspecting officers : A DO R.K.Yadav
9. Name and designation of  
Officer from the building side : Smt.Lata Singh (Principal).
10. Year of Construction : 2002
11. Applicant's letter No : dated 07.05.2015.

NO	Minimum Standards on fire prevention	NBC Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 Mtrs.	10 Mtrs.	MR
	• Gate width	4.5 M	5 M	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	04 Nos.	0 4 Nos.	MR
	A- Block(G+2)	02 Nos.	0 2 Nos.	MR
	B-Block(B+G+3)	02 Nos.	0 2 Nos.	MR
	• Basement in B- Block only	01 Nos.	01 Nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.5 M each	MR
	A- Block(G+2)	1.25 M	1.25 & 1.15 M	MR
	B-Block(B+G+3)	1.5 M	1.5 M each	MR
	• Basement in B-Block only	1.5 M	1.5 M	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 Nos.	03 Nos.	MR
	e. Width of Corridor	1.5 M	1.5 M	MR
	f. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Exhaust Fan	MR
	• Upper floor	N/A	Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	10 Nos.	12 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR



6	First-aid-Hose Reels.			
	Total numbers of each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 MM	5 MM	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	100 MM	MR
	• Number of hydrants per floor	01 No.	01 No.	MR
	• Hose Box	01 No.	01 No.	MR
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	2x 450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	50,000 Ltrs.	MR
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltrs.	15,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A




18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.

This department had already issued fire safety certificate vide this office letter no. F6/DFS/MS/2011/1541 dated 08.07.2011 for basement, ground plus two upper floors.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

  
 Signature of the Inspecting Officer 13/6/2015  
 Name:-R.K.Yadav  
 Designation:-ADO(LN)

DO(ED)