

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2015/W2/1161

Dated: 03/07/15

FIRE SAFETY CERTIFICATE

Certified that the Shopper's Stop Ltd. Located at Eros Mall, Plot No. 10, Shivaji Place, Rajouri Garden, New Delhi - 110027 comprised of Lower Basement + Upper Basement + Ground + 4 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/EH/2011/3124 dated 23-11-2011 The premises was re inspected by the officers concerned of this department on 05-06-2015 in the presence of Sh. Rajesh Gurung (Area Maintenance Head) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 03/07/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/07/15 at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Tel. -011-23424250

Copy to:

1. Sh. Rajesh Gurung (Area Maintenance Head)
Shoppers Stop Ltd at EROS Mall, Plot No-10,
Shivaji Pace, Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'P' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: Shopper's Stop Ltd. At Eros Mall, Plot No. 10, Shivaji Place, Rajouri Garden, New Delhi – 110027.
2. Type of Occupancy : Mall (Lower Basement, Upper Basement, Ground + 4 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2011/3124 Dated 23-11-2011
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2005/621 dated 21-03-2005
6. Date of inspection : 05-06-2015
7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
8. Name and designation of Officer
 from the building side : Sh. Rajesh Gurung (Area Maintenance Head)
9. Year of Construction : 2007
10. Applicant's letter No. : Letter no. Nil Dated 25-05-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	24 m	Provided	MR
	• Gate width	On Main Road	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4	Provided	MR
	• Basements	11	Provided	MR
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	Old Case	Old Case	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Found Functional	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	Inter connected with Detection & alarm system	MR
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Inter connected with Detection & alarm system	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	90 nos.	Provided	MR
	<ul style="list-style-type: none"> Types 	ABC, CO ₂	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	4	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	4	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	4	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	4	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	4500 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of main pump 	100 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	2	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	2X180 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	100 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	4500 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	100 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Staring/Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	1,00,000 litres	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		30, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts: lift lobby is not required being capsule lift, however it is mentioned in the approved drawings.			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	Required	Found Functional	MR
		Required	Found Functional	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/EH/2011/3124 Dated 23-11-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

Mukesh Verma
11/6/15
Mukesh Verma
ASO (MN)

[Signature]
13/16