

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. f6/dfs/ms/2015/w2/1159


Dated: 02/07/2015

FIRE SAFETY CERTIFICATE

Certified that **Storage of Petroleum Class B HSD (20 KL) underground tank for captive use in Hotel premises at Plot No 12, Mangalam Place, Sector – 3, Rohini, New Delhi 110085** Comprised of **Ground Floor only open Shed** owned / occupied by **Seven Seas Hospitality Pvt. Ltd.**, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verified by the officer concerned of this department on **20/05/2015** in the presence of **Mr. H. C Aggarwal** and that the premises fit for occupancy **Class Hazardous (Group - J)** occupancy with effect for from **.02/07/2015** for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. "No Smoking" and "Not to use mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
2. No Trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical / electric spark should be allowed within the premises and its vicinity.
3. 04 no's of Co2 gas type ISI capacity of 4.5 kg, 02 no's of ABC stored pressure power type ISI capacity 05 kg and 01 numbers of AFFF type ISI capacity 50 ltrs provided should be maintained in proper working order all the time.
4. The workers employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
5. Overhead electric cable not passing across the licensed premises.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on .02.. / 07.... /2015 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. Insp. / A & E for Joint Commissioner of Police, Licensing: Police Station (1st floor) Defence Colony: New Delhi.
2. The Authorized signatory, Seven Seas Hospitality Pvt. Ltd, B – 28, Lawrence Road Industrial Area, Near Britania Chowk , New Delhi 110035

INSPECTION REPORT

1. Name & address of the building : Storage of Petroleum class B HSD (20KL) in Hotel premises at Plot no 12, Mangalam Place Sector-3, Rohini
2. Type of Occupancy : **Group J Hazardous Building (Ground floor)**
3. Type of Case : New Case
4. Details of previous NOC : -----
5. Fire Safety directives letter No :
6. Date of inspection : 20/05/2015
7. Name of the Inspecting Officers : DO (NW) S. S. Tuli
8. Name and designation of officers from the building side : Mr. H. C Aggarwal
9. Year of Construction : 2005-2006
10. Applicant's letter No. : F.7 (1184)/2015/6862-64/joint/ C.P/Lic(Pet/Expl) dated 22/04/2015

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Yes	Approachable	M/R ✓
	• Gate width	Yes	Provided	M/R ✓
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1 mtr	110 cm	M.R ✓
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	ISI marked	17 no's	M/R
			ABC, Co2, DCP, & M. Foam	M/R
			Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	30 m 5 mm	N/A	N/A
	<ul style="list-style-type: none"> Length of hose reel hose 		N/A	N/A
	<ul style="list-style-type: none"> Nozzle diameter 		N/A	N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A

	<ul style="list-style-type: none"> ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Terrace level 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Power Supply 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Overhead Tank capacity 	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17	Standby power supply			
		N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A

20	Special Fire Protection Systems for Protection of special Risks, if any:	Fire buckets filled with sand, no smoking boards were found displayed in Hindi & English. No loose electric wiring seen in premises.	
----	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standard on fire prevention and fire safety required under the rules it is recommended to grant fire safety certificate under rules 35 of the Delhi Fire Service Rules 2010

Signature of the Inspecting Officer

Name

Designation

DLFO (1/2)

Signature of the Inspecting Officer

Name

Designation

[Signature]
18/6/15