

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/GH/2015/52/1152

Dated: 02/07/15

FIRE SAFETY CERTIFICATE

Certified that the Amaltas International,(formerly Le Traventino),located at 6,Green Park, New Delhi comprised of Basement, Stilt, Ground and 03 Upper floors but the guest house is running on ground and three upper floors with 30 guest rooms owned/occupied by Sh. Suresh Singh Bahadoria, was granted FSC by this department vide letter No.F6/DFS/MS/GH/2012/3204 dated 04/09/2012.The premises was re-inspected by the officer concerned of this department on 12/06/2015 in the presence of Mr. Prakash Singh Badal and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group A- Residential (Lodging or Rooming House)** with effect from 02/07/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 02/07/15 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

07C

ADD (R&P)

Copy to:-

- (1) Joint Commissioner of Police Licencing
1st Floor, PS Defence Colony, New Delhi
- (2) Sh. Suresh Singh Bahadoria
Director
M/s Amaltas International
Plot no.-6, Green Park
New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Amaltas International(Formerly Le Traventino),6 ,Green Park,
New Delhi - 110024

2. Type of occupancy:- Residential (Guest House)

3. Type of case: - Renewal.

4. Details of previous NOC:-No. F6/DFS/MS/GH/2012/3204 dated 04/09/2012.

5. Fire safety directives No.- No

6. Date of inspection:- 12/06/2015

7. Name of the inspecting officer:- D.B.Mukherjee A.D.O.(BCP)

8. Name & designation of officer From the building side: - Mr. Parkash Singh Badal

9. Year of construction:- 2009

10. Applicant's letter No:- 230-34/Joint.C.P./Lic."(H) New Delhi Dated 13/05/2015,

Building is comprised of Basement, Stilt, Ground + 03 Upper Floors

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1. Access to Building				
	1) Road width	9m	Provided 15 mtr	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2. Number, Width Type & Arrangement of Exits				
A. Number of staircases				
	1. Upper floors	01	Provided	MR
	2. Basements	02	Provided	MR
B. Width of staircase				
	1. Upper floors	1.25 m	1.35mtrs	MR
	2. Basements	1.25 m	1.27m & one exit door of 1.40m	MR
C. Protection of exits				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1m	Provided	MR
3. Compartmentation				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4. Smoke Management System				
	1) Basements	30 a/c per hour	Exhaust Fans	MR
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
5. Fire Extinguishers				
	1) Total numbers	ISI Marked	26Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6. First-Aid Hose Reel				
	1) Total number of each floor	Required 01 no.	Provided	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR

(Signature)

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Not Required	Provided	MR
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	DG Set	MR
	5) Hooter's Location	Required	Provided on every floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants - Not required but provided			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants - Not required but provided			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	Required	450LPM & 180Lpm	MR
	b) Head of pump	Required	30m & 35 m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	Not Required.	Provided 50,000ltr	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 Ltrs.	Provided	MR
15.	Exit Signage.	Required	Not Provided	NMR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided DG Set	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A

20/16

20. Special Fire Protection System for Protection of special Risk, if any:

N/A

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2012/3204 dated 04/09/2012 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature pl.

[Handwritten Signature]
22/6/15

Signature of the inspecting officer
Name: - D.B.Mukherjee.
Designation:- Asstt. Divisional Officer (BCP)

[Handwritten mark]