

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. FD/DFS/MS/FW/2015/52/1511

Dated: 01/07/15

FIRE SAFETY CERTIFICATE

Certified that M/S Sakar Xclusives (opc) Pvt. Ltd. Shop No.4, Sector 12, R.K.Puram, New Delhi-110022 is running the trade of sale and possession of Fire Works at ground floor of the building comprised of ground plus one upper floor owned / occupied by Sh. Rajesh Kalia was granted Fire Safety Certificate by this department vide letter No. F.5/(3A)/DFS/MS/FW/2011/35, dated 02.02.2011. The premises was re-inspected by the officer concerned of this department on 22-06-2015 in the presence of Sh. Rajesh Kalia, Director and found that the said fireworks shop have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Fireworks Storage with effect from 01/07/15.....2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...01/07/15..2015 at New Delhi by.


(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:- 1. Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-49.

2. M/S Sakar Xclusives (opc) Pvt. Ltd. Shop No.4, Sector 12, R.K.Puram, New Delhi-110022.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S Sakar Xclusives (opc) Pvt. Ltd. Shop No.4, Sector 12, R.K.Puram, New Delhi-110022.
2. Type of Occupancy : Storage Fireworks.
3. Type of Case : Old Case
4. Details of Previous NOC : No.F.5/(3A)/DFS/MS/FW/2011/35, Dated 02.02.2011.
5. Fire Safety direction letter No : NIL.
6. Date of Inspection : 22.06.15
7. Name of the Inspecting Officers: : Vedpal (ADO)
8. Name and designation of Officer from the building side : Mr. Rajesh Kalia (Director).
9. Year of Construction : 1984
10. Applicant's letter No : Nil, dated 03.06.15.

S.No	Point of Inspection	Requirement	Provided at Site	Remarks MR/NMR
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9m ²	18.5 m ²	MR
	b. Construction	Pucca	Provided	MR
	c. Premises Location	Not under the staircase / Mean of escape	Provided	MR
	d. Business permissible only at ground floor	Required	Provided	MR.
	e. Business from pavement of road prohibited	Prohibited	Yes	MR
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit.	Required	Provided (Yes)	MR
3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives / inflammable or hazardous materials.	Required 15 m	Provided	MR
4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possessing and sale for fireworks and no other purposes.	Required	Provided (Yes)	MR

5	Type of electrical wiring and electrical fittings.			
	a. Preferably concealed or through conduit	Required	Provided	MR
	b. All electrical fitting should be flame / spark proof	Required	Provided with casing & capping	MR
6	Extension of shop for business			
	Prohibited	Prohibited	Yes	MR
7	Approach road			
	The road width on the side of which premises is located should be 12 m.	12 m	12 m	MR
8	Fire protection arrangement.			
	a. Extinguishers (Type & No's.)	02 no. water type & 1no. of ABC / Co2 Type	Provided	MR
	b. Sand and Water Buckets	2 nos.	Provided	MR
	c. Water Drum (s)	1 no.	Provided	MR
9	Any other point that is contrary to the safety of people.			

The fire protection systems provided in shop were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No. F.5/(3A)/DFS/MS/FW/2011/35, Dated 02.02.2011, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

[Signature] 23/6/15

Signature of the Inspecting Officer

Name Vedpal

Designation ADO

[Signature]
24/6/15

Divisional Officer (South)

