

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No.

FG/DFS/MS/Schad/2015/MD2/1119

Dated:

26/6/15

FIRE SAFETY CERTIFICATE

Certified that the Angels Public Sr. Sec.School at Sahdev Gali,Vishwas Nagar,Shahdara, Delhi-32, owned/occupied by Angels Public Sr. Sec.School , comprising of ground plus three upper floors was granted NOC vide letter no. No.F.6/DFS/MS/2008/2033 dated 21.07.2008.The school building was inspected by the officer concerned of this department on 12.05.2015 & 17.06.15 in the presence of Sh.N.S.Raghave (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and found that the GF+FF+SF+TF of building is fit for occupancy class B "Educational Building" with effect from ....26/6/15... for a period of three years, subject to conditions printed overleaf.

Issued on .....26/6/15..... at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

Copy ll

To,

The Manager  
Angels Public Sr. Sec.School  
Sahdev Gali,Vishwas Nagar,Shahdara, Delhi-32,

Copy to:-

The Director of Education  
GNCT of Delhi, Old secretariat  
Delhi -54.

## - Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

1. Name & address of the building: Angels Public Sr.Sec.School at Sahdev  
Gali,Vishwas Nagar, Shahdara,Delhi -32.
2. Building is comprised of : Ground +3, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter :F.6/DFS/MS/2008/2033 dated 21.07.2008
6. Fire Safety direction letter No :Circular No.262-362 Dated 17.01.2005  
Director of Education
7. Date of Inspection : 12.05.2015 & 17.06.15
8. Name of the Inspecting officers: ADO Suresh Singh
9. Name and designation of Officer:  
from the building side : Sh.N.S.Raghave (Manager).
10. Year of Construction - :1985
11. Applicant's letter No : dated 16/04/15

NO.	Minimum Standards on fire prevention and fire safety U/R33	Old Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 Mtrs.	06 Mtrs.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.20 M & .95 M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
		1 No.	2 No.	MR
	g. Width of Corridor	1.5 M	1.20 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A



5.	Fire Extinguishers			
	• Total numbers	10 Nos.	12 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Siran	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	100 MM	MR
	• Number of hydrants per floor	1 No.	1 No.	MR
	• Hose Box	1 No.	1 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	40 M	40 M	MR
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR



N/5

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
15	• Overhead Tank capacity	5000 Ltrs.	7,500 Ltrs.	MR
16	Exit Signage.	N/A	Provided	MR
	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
17	• Lift Signage	N/A	N/A	N/A
18	Standby power supply	N/A	N/A	N/A
	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
19	• Location	N/A	N/A	N/A
	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
20	• Building Floor Plans	N/A	N/A	N/A
	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS/MS/2008/2033 Dated 21.07.2008 renewal under the circular no.262-362 dated 17.01.2005 is recommended for fire safety certificate.

*Suresh Singh*  
10.6.15

Signature of the Inspecting Officer  
Name:- Suresh Singh  
Designation:-ADO(Shah.)

DO(ED)

*Suresh Singh*