

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. *F6/DFS/MS/School/2015/402/1081* Dated: *26/06/15*

FIRE SAFETY CERTIFICATE

Certified that the Bharat Bharti Public School at S.F.S. Sector - G, New Kondli, Mayur Vihar Phase-III, Delhi-96, owned/occupied by Bharat Bharti Public School comprised of ground plus one upper floor was granted Fire Safety Certificate vide letter no. F.6/DFS/MS/School/2012/854 dated 07.03.12. The school building was inspected by the officer concerned of this department on 18.06.15 in the presence of Smt Neelam Vats (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the GF+FF of building is fit for occupancy class B "Educational Building" with effect from *26/06/15* for a period of three years, subject to conditions printed overleaf.

Issued on *26/06/15* at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Ph.011-23414333

o/c Rk

To,
The Manager
Bharat Bharti Public School
S.F.S. Sector - G, New Kondli,
Mayur Vihar Phase-III, Delhi-96,

Copy to:-
The Dy. Director of Education
D-Block, Anand Vihar, Delhi.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6."The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Bharat Bharti Public School at S.F.S. Sector - G, New Kondli, Mayur Vihar Phase-III, Delhi-96,
2. Building is comprised of : Ground +1 upper floor.
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC : F.6/DFS/MS/School/2012/854 Dated 07.03.12
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11
7. Date of Inspection : 18.06..2015
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer from the building side : Smt.Neelam Vats (Manager).
10. Year of Construction : 2001
11. Applicant's letter No : dated 23.05.2015.

NO.	Minimum Standards on fire prevention and fire safety 3298 to 3398 dated 1.3.11	Circular Requirement	Provided at Site	Remarks
1	Access to building	06 Mtrs.	15 Mtrs.	MR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 No.	2 Nos.	MR
	<ul style="list-style-type: none"> • Upper Floor • Basement 	N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor 	1.25 M	1.25 M & 90 cm	MR
		N/A	N/A	N/A
	<ul style="list-style-type: none"> • Basement 			
	c. Protection of exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01No.	01No.	MR
		1.5 M	1.5 M	MR
	g. Width of Corridor	1.0 Mtrs	1.0 Mtrs	MR
	h. Door Size			
	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers	04 Nos.	08 Nos.	MR
	<ul style="list-style-type: none"> • Total numbers • Types 	ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	1 No.Provided	MR
	• Length of hose reel hose	N/A	30 M	MR
	• Nozzle diameter	N/A	5 MM	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	100 MM	MR
	• Number of hydrants per floor	N/A	1 No.	MR
	• Hose Box	N/A	1 No.	MR
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	Provided	MR
	➤ Discharge of pump	N/A	450 LPM	MR
	➤ Head of the Pump	N/A	40 M	MR
	➤ Power supply	N/A	Provided	MR
	➤ Auto Starting of pump	N/A	Auto	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	Provided	MR
	• Overhead Tank capacity	N/A	5,000 Ltrs.	MR
15	Exit Signage.	N/A	N/A	N/A

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. F.6/DFS/MS/School/2012/854 Dated 07.03.12 is recommended.

Signature of the Inspecting Officer

Name:-R.K.Yadav

Designation:-ADO(LN)

R.K. Yadav 10/10/15