

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SCHOOL/2015/W2/1093

Dated: 26/06/15

**FIRE SAFETY CERTIFICATE**

Certified that the **Guru Nanak Public School** Located at **Pushpanjali Enclave, Pitampura, Delhi-110034** comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/SCHOOL/2012/600 Dated 23-02-2012. The premises was re inspected by the officers concerned of this department on 3/06/2015 in the presence of **Sh. D Batra (AO)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 26/06/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/06/15 at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer  
PH 011-23414250

Copy to:

1. The Principal, Guru Nanak Public School, Pushpanjali Enclave, Pitampura, Delhi-110034

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

- Name & address of the building: Guru Nanak Public School Located as Pushpanjali Enclave, Pitampura, Delhi-110034
- Type of Occupancy : Educational ( Ground + 2 Upper Floor)
- Type of Case : Renewal
- Details of previous NOC : Lt. No. F6/DFS/MS/School/2012/600 Dated 23/2/12
- Fire Safety directives Letter No. : DOE Circular3298-3398 dated 01-03-2011
- Date of inspection : 03-06-2015
- Name of the Inspecting Officer : Udai Vir singh, ADO (WP)
- Name and designation of Officer  
from the building side : Sh. D Batra(AO)
- Year of Construction : 1989
- Applicant's letter No. : Nil Dated -nil

Plot Area - 14016 M<sup>2</sup>  
 Covered Area -5607 M<sup>2</sup>  
 No. or Class Rooms-54  
 No. of Student- 1640

S N o	Minimum standards on fire prevention and fire safety U/R 33	DOE Cr	Provided at site	Remarks
1.	Access of building			
	• Road width	6mtrs	12 mtrs	MR
	• Gate width	4.5 mtrs	5 mtrs	MR
	• Width of internal road	3 mtrs	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	4 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5mtr	1x160cm,1x180cn, 1x175cm &1x110cm	MR
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	MR
	• Pressurization	NR	NR	NA
	d. No of continuous staircase toterrace	<i>one</i>	One Provided	Old case
	e. Width Of Corridor	2 mtrs	Provided	MR
	f. - Door Size	1 mtr	Varies from 95cm to 100cm	Old case

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	20 nos. ABC & CO <sub>2</sub> ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	3 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NR NR NR	NR NR NR	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	NA NA NA	Provided 100 mtrs Provided Provided	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA NA	Provided Provided	NA NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM & 220lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000Ltr	Provided (15000 ltrs)	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel			
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

Note:-General requirements for schools as per Director of Education circular

1. Escape route .....Clear.....
2. LPG cylinders in laboratories Kept in LPG Bank at terrace
3. Electric wiring ...Conduit Wiring..... MCB and ELCB .....  
Electric circuit .....
4. Electric meter board .....Not under the staircase.....
5. Basement use as per BBL 1983 ... NA
6. Emergency telephone no. board ...Displayed.....
7. Generator set .....Nil.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2012/600 Dated 23/02/2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
Officer

Name

*Uday Vir Singh*

Designation

*AO/WP*

Signature of the Inspecting

Name

Designation

