

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfhq_dlfire@nic.in

No. F6/DFS/MS/GH/2015/ MD2/1073

Dated 25/06/15

FIRE SAFETY CERTIFICATE

Certified that the Informal Restaurant, (A Unit of BEL CIBO Hospitality Pvt.Ltd.) 52, Gr. floor & First floor, (Rear Side), Janpath, Connaught Place, New Delhi building is comprised of Ground + Mezzanine + First floor + Second floor + Third floor, Restaurant running at Ground & First floor only have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 16-06-2015 in the presence of Sh. Naresh Madan (Director) that the premises is fit for occupancy of class Assembly Building Group D, Restaurant running at Ground & First rear side floor only with effect from 25/06/15 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...25/06/15..... at New Delhi by.

(Dr. G.C. Misra)
Chief Fire Officer
Ph - 011-23414333

g/c misra

Copy to:-

1. Dr. P.K. Sharma, Medical Officer of Health, Health Department, New Delhi Municipal Council Palika Kendra, New Delhi.
2. Sh. Naresh Madan,
Informal Restaurant, (A Unit of BEL CIBO Hospitality Pvt.Ltd.)
52, Gr. floor & First floor, Janpath, Connaught Place, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Red

INSPECTION REPORT

1. Name & address of the building : Informal Restaurant, (A Unit of BEL CIBO Hospitality Pvt.Ltd.)
52, Gr. floor & First floor, Janpath, (Rear Side) Connaught Place,
New Delhi.
2. Type of Occupancy : Business Building Gr. + Mezzanine + 3 upper floors
(Restaurant running at Ground & First floor only)
3. Type of Case : Fresh
4. Details of previous FSC : F.6/DFS/MS/GH/2015/NDZ/368 dated 15/03/2015
5. Fire Safety directives Letter No. : F.6/DFS/MS/BP/2011/3665 dated 22/12/2011
- 6 Date of inspection : 16/06/2015
- 7 Name of the Inspecting Officer : Sh. Rajesh Panwar (DCFO/NDZ), Sh. G.S. Chaunan (DO/CD) &
Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer
from the building side : Sh. Naresh Madan (Director)
- 9 Year of Construction : 1936
10. Applicant's letter No. : No. MOH/570/D/CMO(Lic.)/SI-V dated 08/06/2015.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements Existing	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9Mtr.	12 mt	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr , 0.90 mtr. & 0.60 mtr.	1.50 mt., 1.80 mtr. & 0.60 mtr.	MR

	Basements	NA	NA	NA
	c..Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	02	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	02 mt	02 mtr. & 1.5 mtr.	MR
	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
	Fire Extinguishers			
	• Total numbers	08	08	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	YES	Provided	MR
	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Gr. floor	Gr. floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA

h.

me

10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Ground Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	100mm	100mm	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	01	01	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level			
	• Discharge of pump	450 LPM	<u>450 LPM 2Nos.</u>	MR
	• Head of the pump	30 mt	30 mt	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA

	<ul style="list-style-type: none"> • Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> • Access to tank 	NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17	Standby power supply	NA	Provided	NA
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, CO ₂	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.

Note:- FSC of 52, Janpath, Connaught place, New Delhi was also granted vide this office letter No. F.6/DFS/MS/GH/2015/NDZ/368 dated 16/03/2015.

Signature of the Inspecting Officer

Name :- S.K. Rajesh Panwar
Designation :- DCFO (NDZ)

12/3/16

Signature of the Inspecting Officer

Name :- G.S Chauhan
Designation :- DO (CD)

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- ADO (CC)