

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2015 / *School/wz/1099*

Dated: *26/06/2015*

FIRE SAFETY CERTIFICATE

Certified that Rishikul Vidyapeeth, Alipur, Delhi-110036 comprised of Ground + Three upper floor (Single block) owned/occupied by Rishikul Vidyapeeth has already been issued fire safety certificate vide letter no. F.6/DFS/MS/School/2012/1251 dated 10/04/2012. The premises was re-inspected by the officer from this department on dated 03/06/2015 in the presence Smt. Alka Dutt (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements in accordance with Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 26 / 06 / 2015 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The means of escape shall always be kept free from any obstruction & unlocked for speedy evacuation of occupants in case of an emergency.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 26/06/15 at New Delhi by

*Santokh Singh*  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. The Principal, Rishikul Vidyapeeth, Alipur, Delhi-110036
2. The Director of Education, Old Secretariat, Delhi

*dc*

**INSPECTION REPORT**Signal block  
Ground + three upper floors

1. Name & address of the building : Rishikul Vidyapeeth Alipur, Delhi-110036
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/School/2012/1251 dated 10/04/2012
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 03/06/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers  
from the building side : Smt. Alka Dutt (Principal)
9. Year of Construction : 2004
10. Applicant's letter No. : RVA/2015-16/1921 dated 25/04/2015

**Plot Area:2759 sq m Covered Area:4532 sq m No. of Students:657 NO. of Class Rooms:30 + 10 room for other purpose & 1 lab**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC PART IV	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	02	02	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr each	1.60 mtr each	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	P	MR
	g. Width of Corridor	—	—	—
	h. Door Size	1.00 mtr	1.08 to 1.13 mtr	MR



3	<b>Compartmentation.</b>			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	• Total numbers	18 ABC	20	MR
	• Types	ISI marked	ABC	MR
	• IS marking		YES	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	Two	P	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter		5 mm	P
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	<b>MOEFA</b>	—	—	—
9	<b>Public Address System.</b>	R	P	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	P	MR
	• Number of hydrants per floor	02	P	MR
	• Hose Box	02	P	MR

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	<b>Pumping Arrangements.</b>			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	900 LPM	P	MR
	➤ Head of the pump	40 m	P	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	10,000 ltr	P	MR
15	<b>Exit Signage.</b>	R	P	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	<b>Standby power supply</b>	—	—	—



18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

**Note:-**General requirements for school as per Director of Education Circular dated...01/03/2011

1. Escape route.....**Clear**.....
2. LPG cylinders in laboratories ...No.....
3. Electric wiring .....**Concealed**.....MCB...**Provided**.....  
Electric circuit.....**ELCB... Provided** .....
4. Electric meter board ..... **Not below S/C** .....
5. Basement use as per BBL 1983..... **N/A** .....
6. Emergency telephone no. board.....**Displayed**.....
7. Generator set.....**No**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F.6/DFS/MS/School/2012/1251 dated 10/04/2012. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name



*[Handwritten signature]*