

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2015/SZ/ 1090

Dated: 26/06/15

FIRE SAFETY CERTIFICATE

Certified that the Vandana Kindergaten School , owned / occupied by Krishna Geetanjali Foundation Society (Regd.) located at Sec-10, Phase-1, Dwarka, New Delhi-110075, comprised of stilt plus three upper floors with basement was granted NOC by this department vide letter no. F6/DFS/MS/School/2357 dated 3.7.2012. The premises was re-inspected by the officer concerned of this department on 9.6.2015 in the presence of Sh. V.P.Tondon(President) and found that the premises have deemed complied with fire prevention and safety requirements in accordance with Directorate of education GNCTD circular no. F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 and that the building / premises is fit for occupancy class B "Educational building" with effect from 26/06/15 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, printed overleaf.

Issued on 26/06/15 at New Delhi by

  
26/6  
(Dr. G.C. Misra)  
Chief Fire Officer  
Ph.011-23414333

Copy to:

1. The Dy. Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-54.
2. Sh. V.K.Tondon, (President) Krishna Geetanjali Foundation Society (Regd.)/  
Vandana Kingergaten School , Sec-10, Phase-1, Dwarka, New Delhi-110075.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

	Name & address of the building	Vandana Kindergarten School run by Krishna Geetanjali Foundation Society(Regd.) Sector 10,Phase-1, Dwarka, New Delhi-110075.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/School/2012/2357 dated 3.7.2012		
5	Fire safety directives letter No	Directorate of Education:F/16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011		
6	Date of inspection	9.4.2015		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. V.P. Tondon (President)		
9	Year of construction	2011-2012		
10	Applicant's letter No.	Nil dated 15.5.2015	(Stilt plus three upper floors) <i>With Basement by</i>	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	Accessible	12 Mtrs.	MR
	2) Gate width	Accessible	6 Mtrs.	MR
	3) Width of internal road	N/A	N/A	MR
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	2 Nos.	2 No.s.	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	Old case	1.51 & .90 Mtrs.	MR
	2. basements	Old case	1.60 & 1.23 Mtrs.	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	1 No.	MR
	e. Width of corridor	Old Case	1.50 to 2.35	MR
	f. Door size	1 Mtr.	1.05 to 1.10 Mtrs.	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Sealed	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 ac charge 12 ac charge	Exhaust fans	N/A
	upper floors		Natural Vent.	MR
5	<b>Fire Extinguishers</b>			
	total numbers	Old case ISI	14 Nos.	MR
	Types		Co2 & ABC	MR
	ISI marking		Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	One	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100MM	100 MM	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	Old Case	450 & 180 LPM	MR
	b. head of the pump	Old Case	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	15000 Ltrs.	15,000 Ltrs.	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/A

17	Standby power supply	Required	Provided	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Co2 & ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules , renewal of FSC issued vided letter no.F6/DFS/MS/School/2012/2357 dated 3.7.2012 is recommended under rules 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

*Sury*  
10/6/15

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designatic ADO (Dwarka)