

C-17

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2015 / W2 / 1267

Dated: 16 / 07 / 2015

FIRE SAFETY CERTIFICATE

Certified that Mata Kasturba Girls Hostel, 47 & 49, Harijan Sevak Sangh, Kingsway Camp, Delhi-110009 comprised of Ground + One floor upper floor with 09 rooms at ground floor only owned/occupied by Mata Kasturba Girls Hostel has already been issued fire safety certificate vide letter no. F.6/DFS/MS/ 2011/747 dated 25/04/2011. The premises was re-inspected by the officer from this department on dated 07/04/2015 in the presence of Mrs. Rosamma (Warden) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of rule 33 of Delhi Fire Service rules 2010, and the building / premise is fit for occupancy of Residential (A) with effect from 16 / 07 / 2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 16/07/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Warden, Mata Kasturba Girls Hostel, 47 & 49 Harijan Sevak Sangh, Kingsway Camp, Delhi-110009
2. Joint Commencer of Police Licensing unit, First floor PS, Defence Colony, New Delhi.

INSPECTION REPORT

Two Blocks.
Gr + One floor, (FSC required for gr. Floor)

1. Name & address of the building : Mata Kasturba Girls Hostel,47 & 49, Harijan Sevak Sangh, Kingsway Camp, Delhi-110009
 2. Type of Occupancy : Residential A-3
 3. Type of Case : Renewal
 4. Details of previous NOC : Letter No. F.6/DFS/MS/ 2011/747 dated 25/04/2011
 5. Fire Safety directives letter No :
 6. Date of inspection : 07/04/2015
 7. Name of the Inspecting Officers : ADO (BW)
 8. Name and designation of officers
from the building side : Mrs. Rosamma (Warden)
 9. Year of Construction : 2002
 10. Applicant's letter No. : 2528 /Joint CP/LIC (H) dated 05/02/2015
- NO. of Rooms:** 9 rooms in both block

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | Accessible | Accessible | MR |
| | • Gate width | — | — | — |
| | • Width of internal road | — | — | — |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | — | — | — |
| | • Upper Floors | — | — | — |
| | • Basements | — | — | — |
| | b. Width of staircases | — | — | — |
| | • Upper Floors | — | — | — |
| | • Basements | — | — | — |
| | c. Protection of exits | — | — | — |
| | • Fire check door | — | — | — |
| | • Pressurization | — | — | — |
| | e. No. of continuous staircases to terrace | — | — | — |
| | g. Width of Corridor | — | — | — |
| | h. Door Size | 1.00 mtr | 1.00 mtr | MR |

| | | | | |
|----|--|-----------------|----------|----|
| 3 | Compartmentation. | — | — | — |
| | • Fire check door | — | — | — |
| | • Sealing of electrical shafts | — | — | — |
| | • Fire Rating of shaft door | — | — | — |
| | • Water Curtain | — | — | — |
| | • Fire Dampers | — | — | — |
| 4 | Smoke Management System. | | | |
| | • Basements | 30 a/c per hour | — | — |
| | • Upper floors | 12 a/c per hour | — | — |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 5 ABC/ CO2 | 5 + 01 | MR |
| | • Types | ISI marked | ABC+ CO2 | MR |
| | • IS marking | | Yes | MR |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | | — | — |
| | • Length of hose reel hose | 30 m | — | — |
| | • Nozzle diameter | 5 mm | — | — |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | — | — | — |
| | • Location of Main Panel | — | — | — |
| | • Location of Repeater Panel | — | — | — |
| | • Alternate source of power | — | — | — |
| | • Hooters' Location | — | — | — |
| 8 | MOEFA | — | — | — |
| 9 | Public Address System. | — | — | — |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | — | — | — |
| | • Upper Floor | — | — | — |
| | • Sprinkler above false ceiling | — | — | — |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | — | — | — |
| | • Number of hydrants per floor | — | — | — |
| | • Hose Box | — | — | — |

| | | | | |
|----|---|---|---|---|
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | — | — | — |
| | • Hose Box | — | — | — |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | — | — | — |
| | ➤ Discharge of main Pump | — | — | — |
| | ➤ Head of Main pump | — | — | — |
| | ➤ Number of main pumps | — | — | — |
| | ➤ Jockey Pump out put | — | — | — |
| | ➤ Jockey pump head | — | — | — |
| | ➤ Standby Pump out put | — | — | — |
| | ➤ Standby Pump Head | — | — | — |
| | ➤ Auto Starting/ Manual stopping | — | — | — |
| | ➤ Pump House Access | — | — | — |
| | • Terrace level | — | — | — |
| | ➤ Discharge of pump | — | — | — |
| | ➤ Head of the pump | — | — | — |
| | ➤ Power Supply | — | — | — |
| | ➤ Auto Starting of pump | — | — | — |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | — | — | — |
| | ➤ Draw-off connection | — | — | — |
| | ➤ Fire service inlet | — | — | — |
| | ➤ Access to tank | — | — | — |
| | • Overhead Tank capacity | — | — | — |
| 15 | Exit Signage. | | | |
| | | — | — | — |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | — | — | — |
| | • Pressurization of Lift lobby | — | — | — |
| | • Communication In lift Car | — | — | — |
| | • Fireman's Grounding Switch | — | — | — |
| | • Lift Signage | — | — | — |
| 17 | Standby power supply | | | |
| | | — | — | — |

| | | | | |
|----|--|---|---|---|
| 18 | Refuge Area. | | | |
| | ➤ Total Area | — | — | — |
| | ➤ Location | — | — | — |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | — | — | — |
| | • Flow Switch Panel | — | — | — |
| | • PA System Panel | — | — | — |
| | • Batter backup | — | — | — |
| | • Building Floor Plans | — | — | — |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | — | — | — |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F.6/DFS/MS/ 2011/747 dated 25/04/2011. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation


D. K. Singh
3/7/15

Signature of the Inspecting Officer

Name

Designation

A. K. Singh
5/6/15
400 (B/D)



11/8/15 D. K. Singh