

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2015/W2/1286

Dated: 17 / 07 / 2015

FIRE SAFETY CERTIFICATE

Certified that Kasturi Ram Collage of Higher Education, Narela, Delhi-40 comprised of Ground + Two upper floor, owned / occupied by Kasturi Ram Collage of Higher Education was issued fire safety certificate by this department vide letter no. F.6/DFS/MS/ 2012/2030 dated 04/06/2012. The premises was re-inspected by the officer concerned of this department on dated 12/05/2015 in the presence of Sh. Rajesh Aggarwal (Chairman) and observed that all the fire safety and fire prevention arrangements as provided in the premises is found in good working condition and there is no additional construction. The premises have therefore deemed complied with requirements under Rule 33 of Delhi Fire Service Rules, 2010 and building / premise is fit for occupancy Sub Group B-2 of Group B Education Building with effect from 17 / 07 / 2015 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, Six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on...17/07/15.....at New Delhi.


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

dc Jy

Copy to:

The Principal, Kasturi Ram Collage of Higher Education, Campus Narela, Delhi-40.

INSPECTION REPORT

Ground + two upper floor.

1. Name & address of the building : Kasturi Ram Collage of Higher Education, Campus Narela,
Delhi-40
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/ 2012/2030 dated 04/06/2012
5. Fire Safety directives letter No : DFS Act 2007 & DFS Rules 2010
6. Date of inspection : 12/05/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Sh. Rajesh Aggarwal (Chairman)
9. Year of Construction : 2005
10. Applicant's letter No. : KRCHE/GGSIPU/001/14-15/6287 dated 18/03/2015 _____

Plot Area:4000 sq mtr **Covered Area:**4080.57 sq mtr **No. of Students:**600 **NO. of Class Rooms:**
14 + 8 room for other purpose and 2 labs

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	02	02	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr each	1.50 mtr each	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	One	Two	MR
	g. Width of Corridor	1.50 mtr	2.00 mtr	MR
	h. Door Size	1.00 mtr	1.00 mtr Double Door	MR

3	Compartmentation.	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	17 ABC	17	MR
	• Types	ISI marked	ABC	MR
	• IS marking		Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One	P	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5 mm	P	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	R	P	MR
10	Automatic Sprinkler System.			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	NR	P	—
	• Number of hydrants per floor	NR	One at each floor	—
	• Hose Box	NR	One at each floor	—

12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	450LPM	P	MR
	➤ Head of the pump	40 M	P	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	10,000 ltrs	P	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—

N-14

Kasturi Ram Collage of Higher Education, Campus Narela, Delhi-110040

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide Letter No. F.6/DFS/MS/ 2012/2030 dated 04/06/2012. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
[Handwritten Signature]
 4/6/15

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
 2/6/15
 ABC(BW)