

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. *f6/dfs/ans/school/2015/1402/1283*

Dated: *17/07/15*

FIRE SAFETY CERTIFICATE

Certified that the EDMC Primary Balika Adarsh Vidyalaya at Khicharipur, Delhi -91, comprised of ground floor only owned/occupied by EDMC Primary Balika Adarsh Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the circular No.F-16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officer concerned of this department on 08.07.2015 in the presence of Mrs. Anita Kumari (Principal) of the school and found that the ground floor of building is fit for occupancy class 'B' 'Educational Building' with effect from *17/07/15* for a period of three years, subject to conditions printed overleaf.

Issued on *17/07/15* at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414000

RLS o/c

To,
The Principal (1st Shift)
EDMC Primary Balika Adarsh Vidyalaya,
Ward No. 219, Khicharipur, Delhi -91

Copy to:-

1. The Dy. Director of Education (EDMC)
Udyog Sadan, Plot No.419,
FIE, Patparganj, Delhi.
2. The Principal (2nd Shift)
EDMC Primary Bal Adarsh Vidyalaya,
Ward No. 219, Khicharipur, Delhi -91.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction if any.
6. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

- INSPECTION REPORT
1. Name & address of the building : EDMC Primary Balika Adarsh Vidyalaya at Khicharipur, Delhi -91.
 2. Building is comprised of : Ground floor only
 3. Type of Occupancy : Educational
 4. Type of Case : New Case
 5. Details of Previous NOC letter : Nil
 6. Fire Safety direction letter No : circular No.F-16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.2011
 7. Date of Inspection : 08.07.2015
 8. Name of the Inspecting officers: ADO R.K. Yadav
 9. Name and designation of Officer:
from the building side : Mrs. Anita Kumari (Principal).
 10. Year of Construction : 1942
 11. Applicant's letter No : letter No. Nil dated 28.05.2015

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 Mtrs.	9 Mtrs.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	N/A	N/A	N/A
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	N/A	N/A	N/A
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • rating of shaft door • Fire Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	3 Nos.	3 Nos.	MR
		ABC & Co2	ABC & Co2	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Length of hose reel hose • Nozzle diameter 	N/A	N/A	N/A
		N/A	N/A	N/A

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Siren	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A

N/4

18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended for Fire Safety Certificate.

R.K. Yadav
8/2/2018

Signature of the Inspecting Officer
Name:-R.K.Yadav
Designation:-ADO (LN)

DO(ED)

Submitted for approval please.

Vijay
12/11/18