

C-17

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/dfs/ans/school/2015/w2/1268 Dated: 16/07/2015

FIRE SAFETY CERTIFICATE

Certified that **Baldev International School, Main Mubarak Pur Road, Inder Enclave, Delhi- 110086** comprised of **Ground + Two upper floor** owned/occupied by **Baldev International School** have complied with the fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act 2007 and Rules 2010 verified by the officer concerned of Fire Service on **02/06/2015** in the presence of **Sh. Jaideep (Manager)** and that the building / premises is fit for occupancy of **Group Class B (Educational)** building with effect from **16/07/2015** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 16/07/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Baldev International School, Main Mubarak Pur Road, Inder Enclave, Delhi-86
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

Single Block

Ground + Two upper floor

1. Name & address of the building : Baldev International School, Main Mubarak Pur Road, Inder Enclave, Delhi- 86
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Details of previous NOC : ----
5. Fire Safety directives letter No : DFS Act 2007 and Rules 2010
6. Date of inspection : 02/06/2015
7. Name of the Inspecting Officers : DO(NW)
8. Name and designation of officers
from the building side : Sh. Jaideep (Manager)
9. Year of Construction : year of construction not verified dealt under DFS Act
10. Applicant's letter No. : Nil dated 05/05/2015

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	01	02	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	1.50 mtr	1) 165 to 180 cms 2) 130 cms	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	M/R
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1 mtr	1.02 mtr	M/R

3	Compartmentation.				
	• Fire check door	N/A	N/A	N/A	
	• Sealing of electrical shafts	N/A	N/A	N/A	
	• Fire Rating of shaft door	N/A	N/A	N/A	
	• Water Curtain	N/A	N/A	N/A	
	• Fire Dampers	N/A	N/A	N/A	
4	Smoke Management System.				
	• Basements	30 a/c per hour	N/A	N/A	
	• Upper floors	12 a/c per hour	N/A	N/A	
5	Fire Extinguishers				
	• Total numbers	One @ 30m ² ISI marked	16 /	M/R	
	• Types		ABC	M/R	
	• IS marking		Yes	M/R	
6	First-Aid Hose Reels.				
	• Total numbers on each floor	One at each floor	P /	M/R	
	• Length of hose reel hose		30 m	P	M/R
	• Nozzle diameter		5 mm	P	M/R
7	Automatic fire detection and alarming system.				
	• Type of detectors	N/A	N/A	N/A	
	• Location of Main Panel	N/A	N/A	N/A	
	• Location of Repeater Panel	N/A	N/A	N/A	
	• Alternate source of power	N/A	N/A	N/A	
	• Hooters' Location	N/A	N/A	N/A	
8	MOEFA	N/A	N/A	N/A	
9	Public Address System.	N/A	N/A	N/A	
10	Automatic Sprinkler System.				
	• Basement	N/A	N/A	N/A	
	• Upper Floor	N/A	N/A	N/A	
	• Sprinkler above false ceiling	N/A	N/A	N/A	
11	Internal Hydrants				
	• Size of riser/down-comer	N/A	N/A	N/A	
	• Number of hydrants per floor	N/A	N/A	N/A	
	• Hose Box	N/A	N/A	N/A	

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	P	M/R
	➤ Head of the pump	40 m	P	M/R
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	P	M/R
15	Exit Signage.			
		N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
		N/A	N/A	N/A
18	Refuge Area.			

N-17

Baldev International School, Main Mubarak Pur Road, Inder Enclave, Delhi- 86

	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note:-General requirements for school as per Director of Education Circular dated 01/03/2011.

1. Escape route..... **Clear**.....
2. LPG cylinders in laboratories ...No.....
3. Electric wiring **Concealed** MCB **Provided**.....
Electric circuit..... **ELCB Provided**.....
4. Electric meter board **Not below S/C**
5. Basement use as per BBL 1983..... **N/A**
6. Emergency telephone no. board..... **Displayed**.....
7. Generator set..... **No**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers...Nil.....

Signature of the Inspecting Officer

Name

Designation

Signature
3/2/15

Signature of the Inspecting Officer

Name

Designation

Signature
3/2/15
Asst (BIO)

Handwritten mark