

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. F6/DFS/MS/EH/2015/W2/1252

Dated: 15/07/15

FIRE SAFETY CERTIFICATE

Certified that **M/s Wildresa & The Sub – Marine (A Unit of Westernised Food Matrix Pvt. Ltd.)** located at **2nd & 3rd Floor, Premises no. 27, NWA Club Road, West Punjabi Bagh, New Delhi** in a building comprised of Basement + Ground + 3 Upper Floors owned/ occupied by **M/s Wildresa & The Sub – Marine (A Unit of Westernised Food Matrix Pvt. Ltd.)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 23-06-2015 in the presence of Mr. Raman Deep Singh (Director) and that the building/ premises is fit for occupancy class “ Assembly” Group D with effect from 15/07/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/07/15 at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: 011 - 23414250.

Copy to:

1. Sh. Raman Deep Singh (Director),
2nd & 3rd Floor, Premises No. 27, NWA Club Road,
West Punjabi Bagh, New Delhi – 110026.
2. Dy. Health Officer, West Zone,
SDMC, Public Health Department,
Vishal Enclave, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s Wildresa & The Sub – Marine (A Unit of Westernised Food Matrix Pvt. Ltd.), 2nd & 3rd Floor, Premises No. 27, NWA Club Road, West Punjabi Bagh, New Delhi – 110026.
2. Type of Occupancy : Assembly (Basement + Ground + 3 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 23-06-2015
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Raman Deep Singh (Director)
9. Year of Construction : 2009
10. Applicant's letter No. : D-3613/HD/WZ dated 10-03-2015

Area = 273 m²

Basement = Empty, Ground Floor = Bank,
First Floor = Hair Clinic

Second & Third Floor = Restaurant

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site | Remarks MR/NMR |
|------|---|------------------|------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 9 m | Provided | MR |
| | • Gate width | NA | On Main Road | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 | Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.5m & 1m | Provided | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NR | NR | NR |
| | • Pressurization | NR | NR | NR |
| | d. No of continuous staircase to terrace | NR | NR | NR |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 2m & 1m | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NR | NR | NR |
| | • Sealing of electrical shafts | NR | NR | NR |
| | • Fire Rating of shaft door | NR | NR | NR |
| | • Water Curtain | NR | NR | NR |
| | • Fire Dampers | NR | NR | NR |

| | | | | |
|-----|--|--|--|--|
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | NA Required | NA Provided | NA MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 10 nos. ABC & CO ₂ ISI marked | Provided Provided Provided | MR MR MR |
| 6. | First – Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 1 30 m 5 mm | Provided Provided Provided | MR MR MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | Smoke & Heat Required Required Required Required | Provided Provided Provided Provided Provided | MR MR MR MR MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | NR | NR | NR |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling | NR NR NA | NR Provided NA | NR MR NA |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | 100 mm 1 1 | Provided Provided Provided | MR MR MR |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NR NR | NR NR | NR NR |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual | 2280 lpm 50 m 1 180 lpm 50 m 2280 lpm 50 m Required | Provided at Terrace Provided at Terrace Provided at Terrace Provided at Terrace Provided at Terrace Provided at Terrace Provided at Terrace Provided at Terrace | MR MR MR MR MR MR MR MR |

| | | | | |
|-----|--|----------------|---------------------|------|
| | stopping | | Terrace | |
| | ➤ Pump House Access | Required | Provided at Terrace | MR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 900 lpm | Provided | MR |
| | ➤ Head of the pump | 40 m | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting | | | |
| | • Under ground tank capacity | 50,000 litres | Provided at Terrace | MR ✓ |
| | ➤ Draw of connection | Required | Provided | MR |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | 10, 000 litres | Provided ✓ | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NR | NR | NR |
| | ➤ Pressurization of lift lobby | NR | NR | NR |
| | ➤ Communication in lift Car | NR | NR | NR |
| | ➤ Fireman's Grounding Switch | NR | NR | NR |
| | ➤ Lift Signage | NR | NR | NR |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

Note: The total water capacity for firefighting tank at terrace level is 50,000 lit+10,000 lit=60000 litres. All the firefighting pumps & tanks are provided at terrace.

Signature of the Inspecting Officer
Name
Designation
MUKESH VERMA
ASD (MN)

Signature of the Inspecting Officer
Name
Designation