

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2015/WZ/1262

Dated: 16/07/15

FIRE SAFETY CERTIFICATE

Certified that the M/s Haze (a unit of Shri Sai Entertainments) located at SF – 22-01 to 22-06 West Gate Mall, Shivaji Place, Rajouri Garden, New Delhi - 110027 was issued FSC vide Letter No. F6/DFS/MS/EH/2012/3522 dated 25-09-2012. The West Gate Mall has already issued FSC vide letter no. F6/DFS/MS/2014/WZ/1011 dated 11-08-2014. The premises was re inspected by the officers concerned of this department on 30-05-2015 in the presence of Mr. Ashok Kumar Nandra (Partenr) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D with effect from 16/07/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...16/07/15... at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: 011 – 23414250.

Copy to:

1. Sh. Ashok Kumar Nandra (Partnet),
M/s Haze (A unit of Shri Sai Entertainments),
SF – 22-01 to SF 22-06, West Gate Mall, Shivaji Place, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as-per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: M/s Haze (A unit of Shri Sai Entertainments), SF – 22-01 to 22-06 West Gate Mall, Shivaji Place, New Delhi – 110027.
2. Type of Occupancy : Class-D(Assembly) Restaurant
3. Type of Case : Renewal (Situating in Mall already issued NOC vide letter no. F6/DFS/MS/2014/WZ/1011 dated 11-08-2014)
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2012/3522 dated 25-09-2012
5. Fire Safety directives Letter No. : FSC Issued to the mall vide letter no. F6/DFS/MS/2014/WZ/1011 dated 11-08-2014
6. Date of inspection : 30-05-2015
7. Name of the Inspecting Officer : Sunil Chawdhary DO (W) & Mukesh Verma, ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Ashok Kumar Nandra (Partner)
9. Year of Construction : 2011
10. Applicant's letter No. : Nil Dated 11-05-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			

2/16

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	900 lpm	Common with the mall	MR
		40 m	Common with the mall	MR
		Required	Common with the mall	MR
		Required	Common with the mall	MR
14.	Captive water Storage for fire fighting: Common with the mall			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	2,50,000 litres	NA
		NA	Provided	NA
		Required	Provided	MR
		NA	Provided	NA
		10,000 litres	30,000 litres Provided(common with mall)	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2012/3522 dated 25-09-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer *Mukesh Verma 2/15*
 Name **MUKESH VERMA**

Signature of the Inspecting Officer
 Name

Designation **ADD (MN)**

Designation

