

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/ school/2015/w2/1181

Dated: 07/07/2015

FIRE SAFETY CERTIFICATE

Certified that the Goodley Public School at B/D-Block, Shalimar Bag, New Delhi-110088, comprised of Basement + Ground + Three Upper Floors (Except Auditorium) owned / occupied by Goodley Public School has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2012/996 dated 20/03/2012. The premises was re-inspected by the officer concerned of Fire Service on 16/06/2015 in the presence of Sh. V.C. Panday (Care Taker) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular F6/Estate/CC/ Fire/Safety/2011/ 3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class-B Educational except auditorium with effect from 07/07/2015 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The auditorium shall not be occupied till clearance form this departments.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. There shall not be more than 45 students in class rooms in any case.
9. The means of escape shall be kept unobstructed and unlocked for speedy evacuation of occupants in case of any emergency.

Issued on 07/07/15 at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
Phone No. 23414250.


Copy to :-

1. The Principal, Goodley Public School, B/D-Block, Shalimar Bag, New Delhi-110088.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

INSPECTION REPORT

1. Name & address of the building: Goodley Public School, B/D-Block, Shalimar Bag,
New Delhi-110088.

2. Type of Occupancy : Educational (Basement + Ground + Three Upper Floors)
(Except Auditorium)

3. Type of Case : Renewal

Total Area = 6474 m ²
Covered Area = 2100m ²
No. of Student = 2820
No. of Rooms = 70

4. Details of previous NOC : F6/DFS/MS/School/2012/996 dated 20/03/2012

5. Fire Safety directives Letter No. : DOE Circular Dated 1/03/2011

6. Date of inspection : 16/06/2015

7. Name of the Inspecting Officer : Udaivir Singh (A.D.O. Wazir Pur)

8. Name and designation of Officer

from the building side : Sh. V.C. Panday (Care Taker)

9. Year of Construction : 1985-89

10. Applicant's letter No. : -5GPS/9/2015/ Dated 23/05/2015

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated 1/3/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2x1.5 mtr	Provided	MR
	• Basements	1x1.5 m & 1x100cm	1x80cm & 1x1.33m	MR(Being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	One	Provided	MR
	e. Width Of Corridor	2 mtr	Provided (Old Case)	MR
	f. Door Size	1.00 mtr	Provided (Old Case)	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	20	25	M/R
		ISI marked	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	Two	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	Provided	MR
	• Hose Box	N/A	Provided	MR
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450LPM, 180 LPM	Provided	MR
	➤ Head of the pump	40MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular

1. Escape route Clear.....
2. LPG cylinders in laboratories Nil.....
3. Electric wiring ... Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter board Not under the staircase.....
5. Basement use as per BBL 1983 ... School activity is going on however the sprinkler are provided
6. Emergency telephone no. board Displayed.....
7. Generator set Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2012/996 dated 20/03/2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name : Udaivir Singh

Designation : A.D.O. (Wazirpur)

Udaivir Singh
16/6/15