

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. F.6/DFS/MS/EH/2015/ 82 /1206

Dated: 08/07/15

FIRE SAFETY CERTIFICATE

Certified that the **M/S Barbeque Nation** located at B-1/623, Janak puri, New Delhi-110058. The building is comprised of basement, ground floor, mezzanine floor, first, second and third floor, but the restaurant is running at ground floor and mezzanine floor only. The above restaurant was issued FSC vide Letter No. No.F6/DFS/MS/EH/2012/1467 dated 24-04-2012 owned/occupied by M/S Barbeque Nation Restaurant. The Restaurant building was re-inspected by the officer concerned of this department on 01.07.2015 in the presence of Sh. Devender Singh Rawat (Restaurant Manager) and found that the M/S Barbeque Nation Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises (**Ground and Mezzanine floor only**) is fit for occupancy class Group "D" assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....08/07/15.....at New Delhi.


(Dr. G.C. Misra)
Chief Fire Officer
Tel: 011-23414333

Copy to:-

1. The Deputy Health Officer,
West Zone (SDMC), Public Health Department,
Vishal Enclave, New Delhi-110027.
2. The Business Manager,
M /S Barbeque Nation,
B-1/623, Janak puri, New Delhi-110058



Restaurant is running at Ground and mezzanine floor only
(M/S Barbeque Nation, B-1/623, Janak puri, New Delhi-110058)

INSPECTION REPORT

1. Name & address of the building : M/S Barbeque Nation, B-1/623, Janak puri, New Delhi-110058.
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of Previous NOC : No.F6/DFS/MS/EH/2012/1467 dated 24-04-2012
5. Fire Safety directives letter No : N/A
6. Date of inspection : 01-07-2015
7. Name of Inspecting Officer : A.D.O Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Devender Singh Rawat (Restaurant Manager)
9. Year of Construction : Before 2008
10. Applicant's letter No. : Letter No. Nil dated Nil

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>--</p> <p>--</p>	<p>12 mtrs.</p> <p>173 cms., 88cms.</p> <p>06 mtrs.</p>	<p>M/R</p> <p>M/R</p> <p>--</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>02 No's</p> <p>02 No's</p>	<p>02 No's</p> <p>02 No's</p>	<p>M/R</p> <p>M/R</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p>--</p> <p>--</p>	<p>112cms, 100cms</p> <p>135 cms, 96cms</p>	<p>M/R Being old case</p> <p>M/R (Being old case)</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization • 	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>
	d. No. of continuous staircases to terrace			
		--	One	--
	e. Width of Corridor	--	98 cms.	--
	f. Door-Size	--	104cmsX210cms	M/R Being old case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>N/A</p> <p>--</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>Sealed</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>--</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Exhaust fans are Provided	Restaurant at ground & mezzanine floor only

Sans

Restaurant is running at Ground and mezzanine floor only
(M/S Barbeque Nation, B-1/623, Janak puri, New Delhi-110058)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		450 LPM, 180 LPM	450 LPM, 180 LPM	M/R
		30 M each	30 M each	M/R
		Required	Provided	M/R
		--	--	--
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		--	Provided	M/R
		N/A	N/A	N/A
		--	5000 Ltrs.	M/R Being old case
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			(No lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	250 KVA	M/R
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N/12

Restaurant is running at Ground and mezzanine floor only
(M/S Barbeque Nation, B-1/623, Janak puri, New Delhi-110058)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the fire safety certificate issued vide letter no. F6/DFS/MS/EH/2012/1467 dated 24-04-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Sandeep
02/7/15

Signature of Inspecting Officer

Name: - Sandeep Duggal

Designation: - Assistant Divisional Officer

~~Signature of Inspecting Officer~~

~~Name: -~~

~~Designation: -~~

D.O. (South West)

~~Tommy~~