

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2015 / school/w2/1200

Dated: 8 / 7 / 2015

**FIRE SAFETY CERTIFICATE**

Certified that N.D.M.C. Primary Boys School, Sector 4-II, Rohini, Delhi comprised of Two Blocks, i.e. (One Block,--- Ground Floor & Second Block, --- Ground + One Upper Floor) owned/occupied by N.D.M.C. Primary Boys School, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 24/06/2015 in the presence of Sh. Rajkumar Goyal (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 8 / 7 / 2015 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**


- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 8/7/15 at New Delhi

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. N.D.M.C. Primary Boys School, Sector 4-II, Rohini, Delhi-110085
2. The Director of Education, North MCD, Civic Centre New Delhi.



**INSPECTION REPORT**

**02 Blocks, one block Ground Floor & Second block Ground + One Floor**

1. Name & address of the building : NDMC Primary boys School, Sector – 4-II, Rohini, Delhi
2. Type of Occupancy : Education (ID. 11354094Boys)
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Director of Education 01/03/2011
6. Date of inspection : 24/06/2015
7. Name of the Inspecting Officers : ADO(RN) Rajesh Kumar
8. Name and designation of officers  
from the building side : Sh. Rajkumar Goyal ( Principal)
9. Year of Construction : 2003
10. Applicant's letter No. : nil dated nil ODD No 1365 dated 27/04/2015

PA- 4600 sq mtr , CA- 1800 Sq. mtr , NOS - 800, NOR – 22 + 01

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	M/R ✓
	• Gate width	Accessible	Accessible	--
	• Width of internal road	--	--	--
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	01	02	M/R ✓
	• Upper Floors	01	02	M/R ✓
	• Basements	--	--	--
	b. Width of staircases	--	--	--
	• Upper Floors	2 <sup>nd</sup> Block 1.5 mtr	1.80 m & 1.50 m	M/R ✓
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace	--	--	--
	e. Width of Corridor	1 mtr x 2	Provided double door of 1 mtr	M/R ✓
	f. Door Size			

3	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N.A.	N.A.	N.A.
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	N.A.	N.A.
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	08	12	M.R ✓
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ISI marked	ABC	M.R ✓
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>		Yes	M.R ✓
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	30 m 5 mm	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>		N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>		N.A.	N.A.
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	N.A.	N.A.	N.A.
8	<b>MOEFA</b>	N.A.	N.A.	N.A.
9	<b>Public Address System.</b>	N.A.	N.A.	N.A.
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	N.A.	N.A.	N.A.
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	N.A.	N.A.	N.A.



NDMC Primary boys School, Sector – 4-II, Rohini, Delhi

	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
17	<b>Standby power supply</b>	N.A.	N.A.	N.A.
18	<b>Refuge Area.</b>			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	<b>Fire Control Room</b>			
	• Detector System Panel	N.A.	N.A.	N.A.
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	N.A.	N.A.	N.A.
	• Batter backup	N.A.	N.A.	N.A.
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

Note: - General requirements for schools as per Director of Education circular dated ..... 01.03.2011.....

1. Escape route ..... Cleared .....
2. LPG cylinders in laboratories ..... N.A. .....
3. Electric wiring ..... Conducte .....
4. MCB and ELCB Electric circuit ..... provided .....
5. Electric meter board ..... Provided near Gate .....
6. Basement use as per BBL 1983 ..... N.A. .....
7. Emergency telephone no. board ..... provided .....
8. Generator set ..... provided .....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Signature of the Inspecting Officer

Name S.S. Tuli

Designation DO/NWD

29/6/15

Signature of the Inspecting Officer

Name RAJESH KUMAR

Designation ADO/RN