

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/GH/2015/W2/11213

Dated: 08/07/15

FIRE SAFETY CERTIFICATE

Certified that the **Manav Residency** located at **2/80, Club Road, West Punjabi Bagh, New Delhi – 110026** comprised of Ground + 2 Upper Floors having 12 rooms, 4 on each floor was issued FSC vide letter no. F6/DFS/MS/GH/2011/3165 dated 25-11-11. The premises was re inspected by the officers concerned of this department on 08-06-2015 in the presence of Mr. Kamal (Manager) and found that the guest house is running with 8 Guest Rooms Three on Ground and Five on First Floor as granted by Addl. CP. Second Floor is lying vacant. The fire safety arrangements were found to be in good working condition. The premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Residential Building” Group A of Sub Division - A 1 with effect from 08/07/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...08/07/15... at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Ph.011-23414250

Copy to:

1. Sh. Prem Chawla, Manav Residence, 2/80 B, Club Road, West Punjabi Bagh, New Delhi.
2. The Joint Commissioner of Police (Lic.), Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Manav Residence, 2/80 B, Club Road, West Punjabi Bagh, New Delhi.
2. Type of Occupancy : Residential (Guest House is located at Ground and First Floor in a building comprised of Ground + 2 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/GH/2011/3165 dated 25-11-11
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 08-06-2015
7. Name of the Inspecting Officer : Mukesh Verma ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Kamal
9. Year of Construction : 1980
10. Applicant's letter No. : Nil Dated 13-05-15 & 39667/Joint C.P./Lic(H) dated 11-10-2014

GF = 3 Guest Rooms

FF = 5 Guest Rooms

SF = Vacant

As mentioned by Addl. CP vide letter no. HTL/ADDL.CP/LIC(H)/2009/104

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	6 m	Provided	MR
	• Road width	NA	NA	NA
	• Gate width	NA	NA	NA
	• Width of internal road			
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	2	2 Provided	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	Old Case	Old Case	MR
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NR	NR	NR
	• Fire check door	NR	NR	NR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1 m	Provided	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical	NR	NR	NR

	shafts			
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	6 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Found Provided	MR
	• Length of hose reel hose	30 m	Found Provided	MR
	• Nozzle diameter	5 mm	Found Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	Required	Found Functional	MR
9.	Public Address System	Required	Found Functional	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA

	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Found Provided	MR ✓
	➤ Head of the pump	40 m	Found Provided	MR
	➤ Power supply	Required	Found Provided	MR
	➤ Auto starting of pump	Required	Found Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	5000 litres	5000 litres Provided	MR ✓
15	Exit Signage	Required	Found Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2011/3165 dated 25-11-11 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

MUKESH VERMA

Name

Designation

ADO (M.N)

Designation