

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F6/DFS/MS/School/2011/3510/1222

Dated: 10/07/15

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Senior Secondary School, Sonia Vihar, Delhi-94, comprised of ground floor plus one upper floor was granted fire safety certificate by this department vide Letter No- F.6/DFS/MS/School/2011/3510 dated 14.12.2011. School building was re-inspected by the officer concerned of this department on 29.06.2015 in the presence of HOS of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the building having GF+FF is fit for occupancy Group B "Educational Building" with effect from ..10/07/15... renewed for a period of three years, subject to conditions printed overleaf.

Issued on...10/07/15.....at New Delhi by



(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

07/08/15

To,

The HOS

Govt. Girls Senior Secondary School, Sonia Vihar, Delhi-94

Copy to:-

1. The Joint Director of Education
(Land & Estate)
Directorate of Education, Lucknow Road, Delhi -54
2. The HOS
Govt. Boys Senior Secondary School, Sonia Vihar, Delhi-94

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Senior Secondary School, Sonia Vihar, Delhi-94
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/School/2011/3510 dated 14.12.2011
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398
dated 01.03.11
7. Date of Inspection : 29.06.2015
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer
from the building side : HOS
10. Year of Construction : 2005/2009
11. Applicant's letter No : GGSSS/SV/2015/24 Dated 28.04.2015

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	4.5 m	6 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	4 no.	5 no.	MR
	Basement	N.A	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	1 no of 1.45 m 4 no. of 1.5 m	MR
	Basement	N.A	N.A.	N.A.
	c. Protection of exits	N.A	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	2 no.	2 no.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
h. Door Size	1 m	1 m	MR	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	N.A.	N.A.	N.A.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.			
		N.A.	N.A.	N.A.
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply			
		N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:			
		N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F.6/DFS/MS/School/2011/3510 dated 14.12.2011 renewal under the circular No. 3298 to 3398 dated 01.03.11 is recommended.

Suresh Singh
1.7.15

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)

DO (EAST)

Submitted for approval please.

Wing