

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO.F6/DFS/MS/2015/ Hospital/52/1306

Dated: 21/07/15

**FIRE SAFETY CERTIFICATE**

Certified that Venu Eye Institute & Research Centre, located at 1/31,Seikh Sarai Institutional Area Phase-2, New Delhi-17, comprised of basement, ground plus two upper floors, owned/occupied by Venu Charitable Society was granted NOC by this department vide letter No. F6/MS/DFS/Hospital/2000/1971 Dated 25/10/2000 The premises was re- inspected by the officer concerned of this department on 03/07/2015 in the presence of Mr. Rakesh and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Institutional (Eye Hospital)** with effect from ~~21/7/15~~-----for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~21/07/15~~-----at New Delhi by.

  
**(Dr. G.C. Misra)**  
**Chief Fire Officer**  
Tel: 011-23414333

  
G.C. Misra  
ADD (2015)

Copy to

Ms. Tanuja Joshi (Secretary)  
Venu Eye Institute & Research Center,  
1/31,Seikh Sarai Institutional Area Phase-2, New Delhi-17

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building:- Venu Eye Institute & Research Center, 1/31, Seikh Sarai Institutional Area Phase-2, New Delhi-17

2. Type of occupancy:- Institutional (Eye Hospital)

3. Type of case:- Renewal

4. Details of previous NOC:- F6/MS/DFS/Hospital/2000/1971 Dated 25/10/2000

5. Fire safety directives No.- F6/DFS/MS/Hospital/98/337 Dated 13/2/1998

6. Date of inspection:- 03/07/2015

7. Name of the inspecting officer:- D.B. Mukherjee, A.D.O. (BCP)

8. Name & designation of officer from the building side:- Mr. Rakesh

9. Year of construction:- 2000.

10. Applicant's letter no:- Nil Dated 13/05/2015

Building is comprised of Shunken Basement, Ground + Two Upper Floors.

S.N o.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	9m	Provided	MR
	2) Gate width	6mtr	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	4 nos	Provided 4nos	MR
	2. Basements	2 nos	Provided 2nos	MR
	B. Width of staircase			
	1. Upper floors	2 m	2m, 2m, 1.04m & 1.04m	MR
	2. Basements	2 m	2m & 2m	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	Provided 2 nos	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Provided Exhaust Fan	MR
	2) Upper floors	12 a/c per hour	Natural ventilation	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	62 Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes MR	
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	03Nos	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR



<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	03nos.	Provided	MR
	3) Hose box	03nos.	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	Required	Provide 5 nos	MR
	2) Hose box	Required	Provided	MR
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	Required	Provided	MR
	a) Discharge of main pump	1800 lpm	1800 lpm	MR
	b) Head of main pump	50m	50m	MR
	c) Number of main pump	2nos.	Provided	MR
	d) Jockey pump out put	210 lpm	210 lpm	MR
	e) Jockey pump head	50m	50m	MR
	f) Stand by pump output	1800 lpm	1800 lpm	MR
	g) Stand by pump head	50m	50m	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	2,50,000ltr	Provided	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000ltrs	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Required	Provided D.G.Set	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A


2/12

<b>19.</b>	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/MS/DFS/Hospital/2000/1971 Dated 25/10/2000 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.



Signature of the inspecting officer

Name :- D.B. Mukherjee.

Designation :- Assistant Divisional Officer.