

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


NO F 6 / DFS / MS / 2015 / SZ / 1326

DATED 22/07/15

FIRE SAFETY CERTIFICATE

Certified that M/s Deepsons South End, M - 10, South Extension Part-II, New Delhi - 110049 comprised of **basement (storage only), ground plus three upper floors (shops)**, owned / occupied by M/s Deepsons South End was granted Fire Safety Certificate by this department vide letter No F6/DFS/MS/2012/2737 dated 26.07.2012. The premises was re-inspected by the officers concerned of this department on **09.07.2015** in the presence of **Mr. Anil Haryani (Partner)** and found that the mercantile building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for **Occupancy Group "F" "Mercantile Building (Mall)"** with effect from 22/07/15 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions as mentioned below.

Issued on 22/07/15 at New Delhi by



(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph - 011-23414333



Copy to :-

M/s Deepsons South End, M - 10, South Extension Part-II, New Delhi - 49

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc may be got verified from the concerned authorities.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in **form "K"** provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this fire safety certificate in **form "J"** six month prior to its expiry.

1	Name & address of the building	M/S, Deepsons South End, M-10, South Extension Part-II, New Delhi-110049.		
2	Type of Occupancy	Mercantile building "F"		
3	Building Comprised of	Basement (Storage), Ground plus three upper floor (Shops)		
4	Type of case	Renewal		
5	Details of previous NOC	F6/DFS/MS/2012/2737, dated 26.07.2011.		
6	Fire safety directives letter No	Nil.		
7	Date of inspection	09.07.2015		
8	Name of the inspecting Officers	ADO Vedpal		
9	Name and designation of officers from the building side	Sh. Anil Haryani (Partner)		
10	Year of construction	2000		
11	Applicant's letter No.	Nil, Dated 02.07.2015		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtr	Provided	MR
	2) Gate width	N.A.	N.A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	01no.	01no.	MR(old case)
	2. basements	02nos.	02nos.	MR(old case)
	b. Width of staircase			
	1. Upper floors	1.25m	1.25m	MR
	2. basements	115cm & 110cm	115cm & 110cm	MR(old case)
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N.A.	N.A	N/A
	d. No. of continuous staircase to terrace	Required	01no.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	1m	MR(old case)
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	Exhaust Fan Provided	MR
	upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers		20 Nos. Provided	MR
	Types		ABC, CO2 ,	MR
	ISI marking	ISI	Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	01no.	01no.	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR


7	Automatic fire detection and alarming system			
	Type of detectors	Required	Somke Detector Provided	MR
	location of Main Panel	Ground Floor	Ground Floor	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	DG Provided	MR
	hooter's location	In all areas	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	Provided	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	01no.	01no.	MR
	hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	house box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	900 & 180LPM	900&180LPM	MR
	b. head of the pump	40m(each)	40m(each)	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	40,000 ltr	40,000 Ltr Provided	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	10,000 ltr	10,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR

18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/MS/DFS/2012/2737, dated 26.07.2012 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

 15/7/15

Signature of the inspecting officer

Name Vedpal

Designation : ADO (SJ)