

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/EH/2015/ w2/1345

Dated: 24 / 07 / 2015

FIRE SAFETY CERTIFICATE

Certified that Pizza Hut (unit of Devyani International Limited) Restaurant located on Ground Floor of Fun City Multiplex Prashant Vihar, Delhi comprised of Two Basement, Ground + Four Upper Floors was granted FSC by this department vide letter no F6/DFS/MS/2011/EH/3540 Dated 15/12/2011. The premises was re-inspected by the officers concerned of this department on 24/06/2015 in the presence of Mr. Ankit (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly building occupancy with effect from 24/07/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of fire safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on. 24/07/15.....at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Dy. Health Officer MCD, Rohini Zone, Sector 5, Rohini Delhi for information
2. Pizza Hut (unit of Devyani International Limited) Restaurant at G-20, Fun City Multiplex Prashant Vihar, Delhi

INSPECTION REPORT

1. Name & address of the building : Pizza Hut (unit of Devyani International Limited)
Restaurant at G-20, Fun City Multiplex Prashant Vihar Rohini.
2. Type of Occupancy : Assembly **(Ground Floor)**
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2011/EH/3540 Dated 15/12/2011
5. Fire Safety directives letter No : ---
6. Date of inspection : 24 / 06 / 2015
7. Name of the Inspecting Officers : DO (NW) & ADO (RN)
8. Name and designation of officers from the building side : Mr. Ankit (Manager)
9. Year of Construction : ---
10. Applicant's letter No. : nil Dated nil ODD No 3060 dated 03/06/2015

	Minimum Standards on fire prevention and fire safety U/R 33	Restaurant guide line of DFS dt 04/11/05	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	4.5 mtr	P	M/R
	• Gate width	---	Not provided at site	---
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 no's	02 exit	M/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	Not required	--	--
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	N/R	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	--	--	--
	f. Door Size	N/R	--	--

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	---	--
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Ventilation of kitchen provided	--
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	One at 300 m ²	Provided	M/R
	<ul style="list-style-type: none"> • Types 		DCP type, 03 W Co2	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	one	Provided in mall	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	P	M/R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	Provided	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	Provided	N/A
8	MOEFA	R	P	M/R
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor 	R	Provided with mall	M/R
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	--	---	--
11	Internal Hydrants			

	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	4"	Provided in common Mall	M/R
		1	1	M/R
		1	1	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		--	--	--
		225 LPM 180 LPM	Provided with Mall	M/R
		--	--	--
		Main + D.G	P	M/R
		R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		5,000 ltr	Provided with Mall	M/R

15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	R	P	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--		--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. **F-6/DFS/MS/2011/EH/3540 Dated 15/12/2011** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

DO/NWD

Rajesh Kumar

Signature of the Inspecting Officer

Name

Designation

Rajesh Kumar
ADO/RN