

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2015/1344

Dated: 24/7/15

FIRE SAFETY CERTIFICATE

Certified that the Taksila Public School at Jyoti Colony Extn., Delhi-94, owned/occupied by Taksila Public School, comprising of ground plus two upper floors was granted NOC vide letter no.F.6/DFS/MS/2009/3916 dated 23.12.2009. The school building was inspected by the officer concerned of this department on 02.07.15 in the presence of Smt.Meera Srivastva (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and found that the GF+FF+SF of building is fit for occupancy class B "Educational Building" with effect from 24/07/15 for a period of three years, subject to conditions printed overleaf.

Issued on 24/07/15 at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333
ofc sh

To,

The Manager
Taksila Public School
Jyoti Colony Extn., Delhi-94

Copy to:-

The Dy. Director of Education
B-Block, Yamuna Vihar, Delhi-53.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building: Taksila Public School at Jyoti Colony Extn., Delhi -94.
2. Building is comprised of : Ground +2, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter :F.6/DFS/MS/2009/3916 dated 23.12.2009
6. Fire Safety direction letter No :Circular No.262-362 Dated 17.01.2005
7. Date of Inspection : 02.07.2015
8. Name of the Inspecting officers : ADO Suresh Singh
9. Name and designation of Officer :02.07.15
from the building side : Smt.Meera Srivastva (Principal).
10. Year of Construction - :2000
11. Applicant's letter No : dated 16.06.2015.


NO.	Minimum Standards on fire prevention and fire safety U/R33	Old Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 Mtrs.	06Mtrs.	MR
		4.5 Mts	4.5 Mts	MR.
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a.Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 Nos	02 Nos.	MR
		N/A	N/A	N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M	1.5 M & 1.05 M	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
		1no.	1 No.	MR
	e. Width of Corridor	1.5 M	2.5 M	MR
	f. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 Nos.	13 Nos.	MR
		ABC & Co2	ABC & Co2	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1no.	MR
	<ul style="list-style-type: none"> • Length of hose reel hose • Nozzle diameter 	30 M	30 M	MR
		5 mm	5 mm	MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	100 MM	MR
	• Number of hydrants per floor	1 No.	1 No.	MR
	• Hose Box	1 No.	1 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	40 M	40 M	MR
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
15	• Overhead Tank capacity	5000 Ltrs.	5000 Ltrs.	MR
16	Exit Signage.			
	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A

17	• Lift Signage	N/A	N/A	N/A
18	Standby power supply	N/A	N/A	N/A
	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
19	• Location	N/A	N/A	N/A
	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
20	• Building Floor Plans	N/A	N/A	N/A
	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS/MS/2009/3916 dated 23.12.2009 renewal under the circular no.262-362 dated 17.01.2005 is recommended for fire safety certificate.


6.7.15

Signature of the Inspecting Officer
Name:-Suresh Singh
Designation:-ADO(Shah.)