

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/W2/2015/1330

Dated 23.07.2015


FIRE SAFETY CERTIFICATE

Certified that the The Mohan's Restaurant (A unit of Mittal Hotel Pvt.Ltd.) located at First Floor 3-4, Central Market, Ashok Vihar, Phase-I, New Delhi – 110052 of a premise comprised of basement, ground floor, first floor and second floor owned/occupied by The Mohan's Restaurant (A unit of Mittal Hotel Pvt.Ltd.) was earlier issued by FSC by this deptt. Vide letter No. F.6/DFS/MS/(EH)/2012/2386 dated 05.07.2012. The premises was re-inspected by the officer concerned of this department on 25.06.2015 in the presence of Sandeep Mittal (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under rule 33 of the Delhi Fire Service Rules, 2010 and thus the building/premises is fit for occupancy class D (Assembly), with effect from 23.07.2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on 23.07.2015 at New Delhi by


Santokh Singh
Chief Fire Officer
Delhi Fire Service

Copy to:

The Authorized Signatory,

The Mohan's Restaurant (A unit of Mittal Hotel Pvt. Ltd)

3-4, Central Market, Ashok Vihar, Phase-I, New Delhi-110052.

May Kindly peruse letter no. nil dated nil received from Authorized signatory for The Mohans Restaurant (A unit of Mittal Hotel Pvt. Ltd) regarding renewal of NOC in r/o **The Mohan's Restaurant** located at Central Market Ashok Vihar Delhi-110052. Accordingly premises was inspected & observed that the restaurant is functioning at first floor of the building having basement, ground floor, first floor & second floor. Fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : **The Mohan's Restaurant** (A unit of Mittal Hotel Pvt. Ltd) located at 3-4, Central Market, Ashok Vihar, Phase-I, Delhi-110052.
2. Type of Occupancy : Class - D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/(EH)/2012/2386 dated 05/07/2012
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 25.06.2015
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Sandeep Mittal (Manager)
9. Year of Construction :
10. Applicant's letter No. : nil dated nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 mtrs ✓	12 mtr	M/R Renewal Case
	• Gate width	1.5 mtr ✓	Provided	M/R
	• Width of internal road	NA.	N.A	Not applicable
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 ✓	Provided	M.R.
	• Upper Floors	02 ✓	Provided	M.R.
	• Basement	3 ✓	Provided	M.R.
	b. Width of staircases			
	• Upper Floors	Old case	1.13 mtr approx.	M.R. being old case
	• Basement	Old case	1 mtr & 90 cm	M.R. being renewal case
	c. Protection of exits			
	• Fire check door	N.R as all the staircase are opening out side at G. floor	N.R	N.R.
	• Pressurization	N.R.	N.R.	N.R.

		Not Required	Halls only	M.R.
	e. Width of Corridor			
	f. Door size	old case	Provided	M.R. being renewal case
3.	Compartmentation.			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.A.	N.A.	N.A.
	• Fire Rating of shaft door	N.A.	N.A.	N.A.
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4.	Smoke Management System.			
	• Basements	Required.	Exhaust Fans are provided	N.R.
	• Upper floors	Required	provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	15	20	M.R.
	• Types	Required	provided	M.R.
	• IS marking	ISI marks Required	provided	M.R.
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	1	provided	M.R.
	• Length of hose reel hose	30 m Required	provided	M.R.
	• Nozzle diameter	5 mm Required	provided	M.R.
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N.R.	N.R.	N.R.
	• Location of Main Panel	N.R.	N.R.	N.R.
	• Location of Repeater Panel	N.R.	N.R.	N.R.
	• Alternate source of power	N.R.	N.R.	N.R.
	• Hooter's Location	N.R.	N.R.	N.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	N.R.	N.P	N.R.
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	M.R.
	• Upper Floor	Required	Provided	M.R.
	• Sprinkler above false ceiling	Required	Provided	M.R.
11.	Internal Hydrants			
	• Size of riser/down-comer	100 m	Provided	M.R.
	• Number of hydrants per floor	1	Provided	M.R.
	• Hose Box	1	Provided	M.R.

12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	Not applicable
	• Hose Box	N.R.	N.R.	Not applicable
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	N.R.
	➤ Head of Main pump	N.R.	N.R.	N.R.
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	60 mtr	Provided	M.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R.
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	Not Required	Not Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	N.R.	N.P.	N.R.
	➤ Overhead Tank Capacity	10, 000 ltrs	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.

	<ul style="list-style-type: none"> • Communication In lift Car 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Lift Signage 	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	Not applicable
	➤ Location	N.R.	N.R.	Not applicable
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	Not applicable
	➤ Flow Switch Panel	N.R.	N.R.	Not applicable
	➤ PA system Panel	N.R.	N.R.	Not applicable
	➤ Batter backup	N.R.	N.R.	Not applicable
	➤ Building Floor plans	N.R.	N.R.	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	M.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F6/DFS/MS/(EH)/2012/2386 dated 05/07/2012 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

Signature of the Inspection Officer

Name Sunil Chawdhary

Designation DO (W)

Signature of the Inspection Officer

Name

Designation