

FIRE SAFETY CERTIFICATE


Certified that M. C Primary School, located at G- Block, Sector – 16, Rohini, Delhi comprised of Two blocks A & B, A- block having ground floor only and B- Block of Ground + One Upper Floor owned/occupied by M. C Primary School has already been issued fire safety certificate vide letter no. F6/DFS/MS/2012/School/2261 dated 25/06/2012. The premises was re-inspected by the officer from this department on dated 07/07/2015 in the presence of Smt. Rajrani (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore complied with the requirements of Circular No. F.16 / Estate / CC / Fire Safety / 2011 / 3298-3398 dated 01/03/2011 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 30 / 07 / 2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 30/07/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250



Copy to:-

1. The Principal, M. C Primary School, at G- Block, Sector – 16, Rohini, Delhi
2. The Director of Education, NMCD, Civic Centre, New Delhi.

INSPECTION REPORT
02 blocks, 1st Block GF + FF, & 2nd Block Ground Floor Only

1. Name & address of the building : M. C Primary School, G-Block, Sector 16, Rohini.
2. Type of Occupancy : Education (ID. 1354070)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2012/School/2261 dated 25/06/2012
5. Fire Safety directives letter No : Director of Education dated 01/03/2011
6. Date of inspection : 07/07/2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Smt. Rajrani (Principal)
9. Year of Construction : 2003
10. Applicant's letter No. : nil dated 06/05/2015

PA- 4150 sq. mtr,

CA- 1550 sq mtr ,

Nos – 420,

NOR-17

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R ✓
	• Gate width	--	--	--
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	01	01	M/R ✓
	• Upper Floors	01	01	M/R ✓
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.5 mtr	2.10 mtr	M/R ✓
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace	01	01	M/R ✓
	e. Width of Corridor	1.50 mtr	02 mtr	M/R ✓
	f. Door Size	1 mtr	1.10 mtr	M/R ✓

3	Compartmentation.			
	• Fire check door	N.A.	N.A.	N.A.
	• Sealing of electrical shafts	N.A.	N.A.	N.A.
	• Fire Rating of shaft door	N.A.	N.A.	N.A.
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	• Basements	30 a/c per hour	N.A.	N.A.
	• Upper floors	12 a/c per hour	N.A.	N.A.
5	Fire Extinguishers			
	• Total numbers	06	06	M.R ✓
	• Types	ISI marked	ABC + Co2	M.R ✓
	• IS marking		Yes	M.R ✓
6	First-Aid Hose Reels.			
	• Total numbers on each floor	30 m 5 mm	N.A.	N.A.
	• Length of hose reel hose		N.A.	N.A.
	• Nozzle diameter		N.A.	N.A.
7	Automatic fire detection and alarming system.			
	• Type of detectors	N.A.	N.A.	N.A.
	• Location of Main Panel	N.A.	N.A.	N.A.
	• Location of Repeater Panel	N.A.	N.A.	N.A.
	• Alternate source of power	N.A.	N.A.	N.A.
	• Hooters' Location	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public Address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	• Basement	N.A.	N.A.	N.A.
	• Upper Floor	N.A.	N.A.	N.A.
	• Sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	• Size of riser/down-comer	N.A.	N.A.	N.A.
	• Number of hydrants per floor	N.A.	N.A.	N.A.
	• Hose Box	N.A.	N.A.	N.A.

12	Yard Hydrants.			
	• Total number of hydrants	N.A.	N.A.	N.A.
	• Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby Pump out put	N.A.	N.A.	N.A.
	➤ Standby Pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/ Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace level			
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the pump	N.A.	N.A.	N.A.
	➤ Power Supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw-off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	• Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	N.A.	N.A.	N.A.
	• Fireman's Grounding Switch	N.A.	N.A.	N.A.
	• Lift Signage	N.A.	N.A.	N.A.

17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	• Detector System Panel	N.A.	N.A.	N.A.
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	N.A.	N.A.	N.A.
	• Batter backup	N.A.	N.A.	N.A.
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

Note: - General requirements for schools as per Director of Education circular dated

1. Escape route **Clear**.....
2. LPG cylinders in laboratories **Not in use**.....
3. Electric wiring **Concealed**.....
4. MCB and ELCB at Electric circuit ... **Provided**.....
5. Electric meter board **Not below stair case**.....
6. Basement use as per BBL 1983 **N/A**.....
7. Emergency telephone no. board **Displayed**.....
8. Generator set **Nil**.....



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F7/DFS/MS/2012/School/2261 dated 25/06/2012. **Renewal** under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

Signature
7/7/15

179/DFS/CO