

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2015/*school/w2/1361*

Dated: *30/07/2015*

FIRE SAFETY CERTIFICATE

Certified that M.C. Primary School, Sector – 20 (NEW), Pkt – 13, Rohini, Delhi comprised of Ground + One Upper Floor owned/occupied by M.C. Primary School, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 10/07/2015 in the presence of Sh. Kulbir Singh (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 30/07/2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 30/07/15 at New Delhi

Santokh Singh
(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

dca

Copy to:

1. The Principal, M.C. Primary School, Sector – 20 (NEW), Pkt – 13, Rohini, Delhi 110085
2. The Director of Education, North MCD, Civic Centre New Delhi.

2-1

INSPECTION REPORT

Ground + One Upper Floor

1. Name & address of the building : M C Primary School, Sector – 20, Pkt 13 Rohini, Delhi
2. Type of Occupancy : Education (ID. 1354115)
3. Type of Case : New Case ✓
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Director of Education 01/03/2011
6. Date of inspection : 10/07/2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers from the building side : Sh. Kulbir Singh (Principal)
9. Year of Construction : 2014
10. Applicant's letter No. : nil dated 07/04/2015

PA- 4011 sq mtr , CA- 1658.38 Sq. mtr , NOS - 800, NOR – 26

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible ✓	Accessible	M/R ✓
	• Gate width	Accessible ✓	Accessible	-- ✓
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	M/R ✓
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.5 mtr ✓	1.50 mtr	M/R ✓
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace	--	--	--
	e. Width of Corridor	1 mtr x 2	Provided double door of 1 mtr	M/R ✓
	f. Door Size			

3	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Water Curtain 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Fire Dampers 	N.A.	N.A.	N.A.
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N.A.	N.A.
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	N.A.	N.A.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	06	06	M.R ✓
	<ul style="list-style-type: none"> • Types 	ISI marked	ABC	M.R ✓
	<ul style="list-style-type: none"> • IS marking 		Yes	M.R ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	N/A ✓	N.A.	N.A.
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	N.A.	N.A.
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Location of Main Panel 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Alternate source of power 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Hooters' Location 	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public Address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Upper Floor 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N.A.	N.A.	N.A.
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N.A.	N.A.	N.A.

M C Primary School, Sector – 20, Pkt 13 Rohini, Delhi

	<ul style="list-style-type: none"> • Fireman’s Grounding Switch • Lift Signage 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	• Detector System Panel	N.A.	N.A.	N.A.
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	N.A.	N.A.	N.A.
	• Batter backup	N.A.	N.A.	N.A.
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

Note: - General requirements for schools as per Director of Education circular dated

1. Escape route *clear*
2. LPG cylinders in laboratories *nil*
3. Electric wiring *conduit/concealed*
4. MCB and ELCB Electric circuit *Provided*
5. Electric meter board *not below staircase*
6. Basement use as per BBL 1983 *N/A*
7. Emergency telephone no. board *displayed*
8. Generator set *N/A*

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DEFO (W2)

Signature of the Inspecting Officer

Name

Designation

Bush
16/1/15
DO (NW)