

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/EH/2015/ 1384

Dated: 31.07.2015

FIRE SAFETY CERTIFICATE

Certified that the **Mughal Mahal Restaurant** located at Sethi Bhawan, 7, Rajindra Place, New Delhi-110008. The building is comprised of lower ground floor, ground floor plus six upper floors. The restaurant is running at lower ground floor only with two exits was issued NOC by this department vide letter No.F.6/DFS/MS/EH/2012/2894 dated 07.08.2012 owned/occupied by the management of Mughal Mahal Restaurant. The Restaurant was re-inspected by the officers concerned of this department on 23.07.2015 in the presence of Sh. Rajesh Kalra (Manager) & Sh. Surender Singh (Estate Manager) and found that the management of Mughal Mahal Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on..... 31.07.2015at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph: 011-23414333

Copy to:-

1. Sh. Rajesh Kalra (Manager),
Mughal Mahal Restaurant,
Sethi Bhawan, 7, Rajindra Place,
New Delhi-110008.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

The building is comprised of Lower Ground, Ground Floor plus six upper floors.

Note:- The restaurant is running at Lower Ground Floor only.

N/H.

INSPECTION REPORT

1. Name & address of the building : Mughal Mahal Restaurant, Sethi Bhawan, 7, Rajinder Place, N.D.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/EH/2012/2894 Date 07.08.2012
5. Fire Safety directives letter No : —
6. Date of inspection : 23.07.2015
7. Name of Inspecting Officer : D.O S.K. Tomar & A.D.O P.S. Dahiya
8. Name and designation of officers From the building side : Sh. Rajesh Kalra (Manager)
9. Year of Construction : Before 1980
10. Applicant's letter No. : Nil dated 14.07.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	<u>Accessible</u>	<u>18mtr</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>200cms</u>	<u>MR</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>One</u>	<u>One</u>	<u>MR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	b. Width of staircases			
	• Upper Floor	<u>—</u>	<u>120 cms</u>	<u>MR, Old Case</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	c. Protection of exits			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	d. No. of continuous staircases to terrace	<u>—</u>	<u>One</u>	<u>—</u>
	e. Width of Corridor	<u>—</u>	<u>240cms, 150cms</u>	<u>—</u>
	f. Door Size	<u>—</u>	<u>103cms x 205cms 98 x 205cms</u>	<u>—</u>
3.	Compartmentation			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Sealing of electrical shafts	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Rating of shaft door	<u>—</u>	<u>—</u>	<u>—</u>
	• Water Curtain	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Dampers	<u>—</u>	<u>—</u>	<u>—</u>
4.	Smoke Management System			
	• Basements	<u>30 a/c per hour</u>	<u>—</u>	<u>No Basement</u>
	• Upper floors	<u>—</u>	<u>—</u>	<u>Lower Ground Floor only</u>

N/12

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	08 Nos	Provided	MR
	• Types	ABC, CO ₂ , DCP	- do -	
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Two	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	Required	Provided	MR (Only in Restaurant)
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	100 M.M	100 M.M	MR
	• Number of hydrants per floor	Two	Two	MR (In Restt. Area only)
	• Hose Box Restaurant Area	- do -	- do -	- do -
12.	Yard Hydrants			
	• Total number of hydrants	One	One	MR
	• Hose Box	- do -	- do -	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
		-	-	-

M/13

Sethi Bhawan, 7, Rajindra Place,
New Delhi - 110008.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		-	900 LPM, 220 LPM	MR (02 Pumps)
		30M Required	30 M Each Provided	-do-
		-	-	MR
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	-	-
		-	Provided	MR
		-	-	-
		-	50000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	Lower Ground only
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
17.	Standby power supply	Required	D.G. Set of 62.5 KVA	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		Required	Provided	MR
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

10

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/EH/2012/2894 dated 07.08.2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


28/7/15

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer




25/7/15

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer