

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F.6/DFS/MS/School/2015/ W2/1392

Dated: 04/08/15

FIRE SAFETY CERTIFICATE

Certified that the building of Sarvodaya Vidyalaya (Without Auditorium) Located at Mansarover Garden, New Delhi -110015 comprised of Ground + 2 Upper Floor & G+1 Upper Floor owned and occupied by Sarvodaya Vidyalaya, Mansarover Garden have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 17-07-2015 in the presence of Sh. Meena (A. E. Civil, PWD) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from ...04/08/15... for a period of three years subject to compliance of the conditions mentioned below:-

Issued on04/08/15..... at New Delhi.


(Santokh Singh)
Chief Fire Officer,
Phone No. 23414250

Copy to:-

1. The Principal,
Sarvodaya Vidyalaya, Mansarover Garden F Block, New Delhi -110015.
2. Director of Education,
Old Hindu College, Old Secretariat Building, Delhi.

o/c R/31/7

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be v-erified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The auditorium / M.P hall shall not be used till fire safety clearance is received from this department.

INSPECTION REPORT

1. Name & address of the building: **Sarvodaya Vidyalaya, Mansarover Garden, New Delhi - 110015.** (without Auditorium)
2. Type of Occupancy : Educational 2 Blocks (Ground + 1 Upper Floor & Ground + 2 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
6. Date of inspection : 17-07-2015
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer
 from the building side : Sh. Meena (A. E. Civil, PWD)
 Year of Construction : 1985
9. Applicant's letter No. : PWD/M-131(N) dated 17-06-2015

Area of School -11100 m²
 Covered Area -4550 m²
 Class Rooms – 56
 Total Students – 2028.

S No	Minimum standards on fire prevention and fire safety U/R	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided ✓	MR
	• Gate width	Accessible	Provided ✓	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 in each block	Provided ✓	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m in each block ✓	G+2=2X135cm, G+1=135cm, ✓	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1 m	Provided double doors ✓	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA

	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	2X450 lpm Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings~~ as noted at serial numbers

Signature of the Inspecting Officer *[Signature]* 20/7/15
Name

Signature of the Inspecting Officer
Name

