

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No: F.6/DFS/MS/School/2015/ W2/1430

Dated: 06/08/15

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Co. Ed Sr. Sec. School (Without Auditorium), located at A-6, Paschim Vihar, New Delhi – 110063. comprised of 2 Blocks of Ground +1 Upper Floor only , owned and occupied by Govt. Co. ed Sr. Sec. School have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 17-07-2015 in the presence of Sh. M S. Sangwan (Principal) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from 06/08/15.. for a period of three years subject to compliance of the conditions mentioned below:-

Issued on ..06/08/15... at New Delhi.

  
(Santokh Singh)  
Chief Fire Officer,  
Ph: 011 – 23414250.

Copy to:-

1. The Principal,  
Govt. Co.ed Sr. Sec.School A-6, Paschim Vihar, New Delhi – 110063
2. Director of Education,  
Old Secretariat Building, Delhi.

0/6 @  
3/8/15

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The auditorium shall not be used for any purpose till clearance is received from this deptt.

## INSPECTION REPORT

1. Name & address of the building: Govt. Co – Ed Senior Secondary School, A – 6, Paschim Vihar, New Delhi – 110063. **(Without Auditorium)**
2. Type of Occupancy : Educational 2 Blocks (Ground + 1 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
6. Date of inspection : 17-07-2015
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer  
from the building side : Sh. M.S. Sangwan (Principal)
9. Year of Construction : 1993 and New Block 2013
10. Applicant's letter No. : A-6/PV/1958 dated 11-06-2014 & 20 (Fire Fighting) PWD/M-131(W)/1207 dated 17-6-15

S No	Minimum standards on fire prevention and fire safety U/R	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>Accessible</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Provided</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> <li>a. Number of staircases</li> <li>• Upper floors</li> <li>• Basements</li> <li>b. Width of staircases</li> <li>• Upper floors</li> <li>• Basements</li> <li>c. Protection of exits</li> <li>• Fire check door</li> <li>• Pressurization</li> <li>d. No of continuous staircase to terrace</li> <li>e. Width Of Corridor</li> <li>f. Door Size</li> </ul>	<ul style="list-style-type: none"> <li>2 in each block</li> <li>NA</li> <li>New Block 2X1.5m</li> <li>Old Block 2 Staircase</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>1.5m</li> <li>1 m</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>NA</li> <li>New Block 2X153cm</li> <li>Old Block 142 cm &amp; 144 cm</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>Provided</li> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> </ul>
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> </ul>





	<ul style="list-style-type: none"> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~ .....

**Note:** FSC is recommended for the school building only without auditorium. The auditorium is under renovation.

Signature of the Inspecting Officer  
Name  
Designation

*MUKESH VERMA*  
ADD(MN)

Signature of the Inspecting Officer  
Name  
Designation

*DO (West)*



*cf/1072*  
*31/7/15*  
*5/8/15*  
*252/1068(10)*

*dh*  
*20/7/15*