

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F-6/DFS/MS/CNG/2015/MOZ/1456.

Dated: 12/08/15

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Site No. 2, Integrated Freight Complex, Gazipur, Delhi, comprised of ground floor only owned/occupied by Indraprastha Gas Limited, was granted NOC by this department vide letter No. F5/(3A)/DFS/CNG/2007/281 dated 27.06.2007. The Premises was re-inspected by the officer concerned of this department on 24.07.2015 in the presence of Operator and found that the CNG station have deemed complied with the fire prevention and fire safety requirements in accordance with the earlier directive issued vide letter no.F.5(3A)/DFS/CNG/2005/526 dt.3.11.05 and found that the CNG Station having GF is fit for occupancy class "CNG Filling Station Group J", with effect from 12/08/15 for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 12/08/15 at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Ph- 011- 23414333

O/c R/L

To,

The General Manager (Fire & Safety)
IGL Bhawan, Plot No. 4, Community Centre,
R.K. Puram Sec-9, New Delhi-22

Conditions

1. No trade susceptible to cause ignition to CNG by generating heat, mechanical/electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipments, electrical gadgets and fitting in the premises shall conform to hazardous area classification for that purpose and be of a type approved by the CCE.
3. In premises "No Smoking" signs board both in Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All fire protection arrangements shall be maintained.
5. Nothing contravention of the Explosive Act. 1884 & Rules their under 1983, Gas Cylinder Rules 2004 and Static & Mobile pressure vessels (Unfired) Rules 1981 as modified upto date. The comments of Chief Controller of Explosive thereof should be permitted.
6. All comments/directions of the Chief Inspector of Explosives should always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : CNG Station at Site No. 2, Integrated Freight Complex, Gazipur, Delhi
2. Building is comprised of : Ground Floor
3. Type of Occupancy : CNG Storage & Dispensing unit (Group J)
4. Type of Case : **Renewal**
5. Details of Previous NOC : F5/(3A)/DFS/CNG/2007/281 dated 27.06.2007
6. Fire Safety direction letter No : F5/(3A)/DFS/CNG/2005/526 dated 03.11.2005
7. Date of Inspection : 24.07.2015
8. Name of the Inspecting Officers: : ADO R.K. Yadav
9. Name of the designation of Officer
from the building side : Operator
10. Year of Construction : 2004
11. Applicant's letter No : IGL/F&S/2014-15/15/14/01 dated 03.07.2015

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12 m	20 m	MR
	Gate width	NA	NA	NA
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	N.A	N.A	N.A
	Width of Staircases	N.A	N.A	N.A
3	Compartmentation.			
	Sealing of electrical shafts	Required	Provided	MR
4	Smoke Management System	Required	Provided	MR
5	Fire Extinguisher			
	Total numbers	28 no.	28 no.	MR
	Types			
	• DCP 10 Kg	17 no.	17 no.	MR
	• DCP 75 Kg Trolley	05 no.	05 no.	MR
	• CO ₂ 4.5 Kg	06 no.	06 no.	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	Type of detectors	Gas	Provided	MR
	Location of main panel	Required	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters	Required	Provided	MR

8	MOEFA	NA	NA	NA
9	Public address System.	N.A	N.A	N.A.
10	Automatic Sprinkler System.	N.A	N.A	N.A.
11	Internal Hydrants	N.A	N.A	N.A.
12	Yard Hydrants.	N.A	N.A	N.A.
13	Pumping Arrangements.			
	• Terrace Level	N.A	N.A	N.A.
	➤ Discharge of pump	N.A	N.A	N.A.
	➤ Head of the Pump	N.A	N.A	N.A.
	➤ Power supply	N.A	N.A	N.A.
	➤ Auto Starting of pump	N.A	N.A	N.A.
14	Captive Water Storage for Fire Fighting.			
	Overhead Tank capacity	N.A	N.A	N.A.
15	No Smoking Sign Board	Required	Provided	MR
16	Provision of Lifts.	N.A	N.A	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	N.A	N.A	N.A.
19	Fire Control Room	N.A	N.A	N.A.
20	Special Fire Protection systems			
	CO ₂ DCP Local Application	Required	Provided	MR
	Hand Held Explosive Meter	02 nos.	Provided	MR

The fire protection systems provided in the CNG Station were tested/ checked and found functional at the time of inspection. The CNG Station was issued NOC earlier vide letter no. F5/(3A)/DFS/CNG/2007/343 dated 14.08.2007.

Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required as per OISD-179, renewal of fire safety certificate is recommended.

R. K. Yadav
31/7/2015

Signature of the Inspecting Officer

Name:- R.K. Yadav

Designation:- ADO (LN)