


No.P6/MS/DFS/GH/2015/ 32 | 1461

Dated: 12/08/15

FIRE SAFETY CERTIFICATE

Certified that the Hotel Flight Path, located at Plot No. A/62, Road No. 4, Gali No.6, Mahipalpur, New Delhi-110037 comprised of basement, ground & 03 upper floors owned/occupied by Hotel Flight Path. The said guest house is running in ground and three upper floors. Basement: sealed, Ground floor- Reception + 3 guest rooms + Office, 1st floor- 5 guest rooms, 2nd floor-5 guest rooms, 3rd floor-3 guest rooms Total- 16 Guest Rooms). The premises was inspected by the officer concerned of this department on 04/08/2015 in the presence of Mr. NarenderKumar and observed that the said guest house building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-A, Residential (Lodging and Rooming House) with effect from ~~12/08/15~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~12/08/15~~ at New Delhi by.



(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph: - 011-23414333

DIRECTOR  
Copy to:-

1. DHO(NG Zone)  
South Delhi Municipal Corporation  
Public Heath Department, Najafgarh Zone  
New Delhi
2. Mr. Vijay Kumar Nangalia  
Hotel Flight Path, Plot No. A/62,  
Road No. 4, Gali No.6, Mahipalpur, New Delhi-110037



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1	Name & address of the building	M/s Flight Path Guest House, Plot No. A/62, Road No. 4, Gali No.6, Mahipalpur, New Delhi-110037.
2	Type of Occupancy	Lodging or Rooming (Guest House)
3	Building comprised of	<b>Basement, ground plus three upper floors</b> , (Basement - Seald ground floor- reception + 3 Guest rooms + Office , 1st floor- 5 Guest Rooms , 2nd floor-5 Guest rooms, 3rd floor-3 Guest rooms <b>Total- 16 Guest Rooms</b> ).
4	Type of case	New
5	Details of previous NOC	No
6	Fire safety directives letter No	Nil
7	Date of inspection	5.8.2015
8	Name of the inspecting Officers	D.B. Mukherjee ADO (BCP)
9	Name and designation of officers from the building side	Sh. Narinder Kumar
10	Year of construction	2005
11	Applicant's letter No.	Nil, dated: 31/07/2015

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 Mtrs	Provided	MR
	2) Gate width	Required	Direct Access from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	1	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.25 Mtr	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to tetrace</b>	Required	One provided	MR
	e. Width of corridor	1.25 Mtr	Provided	MR
	f. Door size	1 Mtr	Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	12 N/A	MR
	upper floors	a/c per hour	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	total numbers		10 Nos. Provided	MR
	Types	ISI	ABC, CO2 Provided	MR
	ISI marking		Provided	MR

	total numbers on each floor	One	Provided	
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	<b>Automatic Fire Detection &amp; Alarming System</b>			
	Type of detectors	N/A	N/A	
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	Provided	N/A
9	<b>Public Address System.</b>	N/A	N/A	MR
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	house box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	900 LPM	900 LPM & 180 LPM provided	MR
	b. head of the pump	35 Mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	d. Over head tank Capacity	10,000 Ltr	10,000 Ltr Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. Pressurization of lift lobby	N/A	N/A	N/A
	c. Communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR

### INSPECTION REPORT

1	Name & address of the building	M/s Flight Path Guest House, Plot No. A/62, Road No. 4, Gali No.6, Mahipalpur, New Delhi-110037.
2	Type of Occupancy	Lodging or Rooming (Guest House)
3	Building comprised of	<b>Basement, ground plus three upper floors</b> , (Basement - Seald ground floor- reception + 3 Guest rooms + Office , 1st floor- 5 Guest Rooms , 2nd floor-5 Guest rooms, 3rd floor-3 Guest rooms <b>Total- 16 Guest Rooms</b> ).
4	Type of case	New
5	Details of previous NOC	No
6	Fire safety directives letter No	Nil
7	Date of inspection	5.8.2015
8	Name of the inspecting Officers	D.B. Mukherjee ADO (BCP)
9	Name and designation of officers from the building side	Sh. Narinder Kumar
10	Year of construction	2005
11	Applicant's letter No.	Nil, dated: 31/07/2015

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 Mtrs	Provided	MR
	2) Gate width	Required	Direct Access from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	1	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.25 Mtr	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to tetraace</b>	Required	One provided	MR
	e. Width of corridor	1.25 Mtr	Provided	MR
	f. Door size	1 Mtr	Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	12 N/A	MR
	upper floors		Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	total numbers		10 Nos. Provided	MR
	Types	ISI	ABC, CO2 Provided	MR
	ISI marking		Provided	MR

216

18	<b>Refuge Area.</b>			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	<b>Fire control room</b>			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no.F6/DFS/MS/GH/2015/SZ/1632 dated: 21/07/2015 has been rectified.

The owner has submitted a declaration that the basement will not be used by them and kept sealed. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010.

**Accordingly DFA is put up for your approval and signature please.**

*Mukherjee*  
31/8/14

Signature of the inspecting officer

Name :- D.B. Mukherjee

Designation : A.D.O (BCP)