

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Indl./2015/WZ/ 1463

Dated: 13/08/2015

FIRE SAFETY CERTIFICATE

Certified that the Lucky Polymers at Plot No. J-1, Udyog Nagar Industrial Area, Rohtak Road, Delhi- 110041 comprised of Basement, Ground, Mezz. Floor & 1<sup>st</sup> Floor only owned / occupied by Lucky Polymers have complied with the Fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified the officers concerned of Fire Service on 09/07/2015 in presence of Sh. Ravinder Malhotra and that the building / premises is fit for occupancy class "Industrial" Group 'G' with effect from / /2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions printed below.

Issued on ..... 13/08/15 ..... at New Delhi.

  
(SANTOKH SINGH)  
CHIEF FIRE OFFICER  
PHONE:23414250

Copy to :-

1. Sh. Ravinder Malhotra, Lucky Polymers, Plot No. J-1, Udyog Nagar Industrial Area, Rohtak Road, Delhi- 110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

1. Name & address of the building: Lucky Polymers, Plot No. J-1, Udyog Nagar  
Industrial Area, Rohtak Road, Delhi- 110041.
2. Type of Occupancy : Industrial Plot Area – 811m<sup>2</sup>
3. Type of Case : New (B.,GF, Mezz. Floor & 1<sup>st</sup> Floor)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/84/BP/367 dated 1.05.1984
6. Date of inspection : 09/07/2015
7. Name of the Inspecting Officer : A. K.-Jaiswal
8. Name and designation of Officer  
from the building side : Mr. Ravinder Malhotra
9. Year of Construction : 1985-86
10. Applicant's letter No. : -Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	15 mtr.	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	3 mtr.	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.40 mtr	Provided	MR ✓
	• Basements	1.40 mtr	Provided	MR ✓
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	As per sanctioned plan	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.20 mtr.	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	15	16	MR
	• Types	ISI marked ABC/CO <sub>2</sub> /WCO <sub>2</sub>	Provided	MR



	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	2	Provided	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30Mtr.	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5mm.	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detector</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power supply</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NR	NR	NR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	➤ Discharge of pump	900Lit/min.	Provided	MR
	➤ Head of the pump	30 mtr.	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	50,000 lts. (As per guidelines)	Provided	M/R
	➤ Draw of connection	Not Required as per guidelines	NR	NR
	➤ Fire service inlet	Not Required as per guidelines	Provided	M/R

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- Building plans has already been approved by this department vide letter No. F6/DFS/MS/84(B)/367 dated 01/05/1984. On the basis of this recommendations. Inspection of this premises is carried out.

*Ashok Kumar Jaiswal*  
9/7/15

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)