

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/dfs/ms/school/2015/w2/1467

Dated: 13 / 08 / 2015


FIRE SAFETY CERTIFICATE

Certified that Murti Devi Public School, D-23, Inder Enclave, Phase-II, Mubarak Pur Road, Village Nithari, Delhi-110086 located on ground + two upper floors of a premise comprised of basement, ground + two upper floors owner / occupied by Murti Devi Public School have complied with the fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 21/05/2015 in the presence of Smt. Nirmal Gaur (Principal) and that the building / premises is fit for occupancy of Group Class B (Educational) building with effect from 13 / 08 / 2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The basement sealed by the school shall not be used for any purpose.
- 4 The means of escape shall not be obstructed and kept locked from outside, for easy escape of occupants in case of any emergency.
- 5 The trained fire fighting staff should be available round the clock.
- 6 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 7 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 9 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/08/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Murti Devi Public School, D-23, Inder Enclave, Phase-II, Mubarak Pur Road Village Nithari, Delhi-110086
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORTBldg- B+Gr+Two+Floors
Basement-Sealed with Brick Wall
Gr+Two Floor School Running

1. Name & address of the building : Murti Devi Public School, D23, Inder Enclave, Ph-II, Mubarak Pur Road Village Nithari, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : New Case ✓
4. Details of previous NOC : Letter No. ___ Nil ___ Dated: ___ Nil ___
5. Fire Safety directives letter No : DFS Act 2007, & Rules 2010.
6. Date of inspection : 21/05/2015 ✓
7. Name of the Inspecting Officers : ADO (BW) ✓
8. Name and designation of officers
from the building side : Smt. Nirmal Gaur (Principal) ✓
9. Year of Construction : 2009 + 2012
10. Applicant's letter No. : ___ Nil ___ Dated ___ 07/11/2014
- Plot area:-1200 m2 Covered area:-2000 m2 No.'s of Student:-350 No.'s of Classrooms:-22
2 room for other purpose

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As Per NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible ✓	MR
	• Gate width	Do	Do Provided ✓	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	—	—	—
	b. Width of staircases			
	• Upper Floors	1.50 mtr	1.52 & 1.53 mtr	MR
	• Basements	NA	NA	Sealed with brick wall affidavit attached as C/8
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	P	MR
	g. Width of Corridor	—	—	—
	h. Door Size Hall	1.50 mtr D.D. CR- 1.00 mtr	1.50 mtr D.D. 1.00 mtr	MR MR

3	Compartmentation.	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	8 ABC	12	M/R
	• Types		ABC	M/R
	• IS marking	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One	P	M/R
	• Length of hose reel hose	30 m	P	M/R
	• Nozzle diameter	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	450 LPM	P	MR
	➤ Head of the pump	40 m	P	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	10,000 ltr	P	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

Note:-General requirements for school as per Director of Education Circular dated 01/03/2011

1. Escape route.....**Clear**.....
2. LPG cylinders in laboratories**No**.....
3. Electric wiring ...**Concealed of conduit..MCB and ELCB Provided**.....
4. Electric meter board ...**Not Below**.....**S/C**.....
5. Basement use as per BBL 1983.....**N/A**.....
6. Emergency telephone no. board...**Displayed**.....
7. Generator set.....**No**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....Nil.....

Note:- The premises is comprised of basement, ground floor and two upper floors. The school has requested NOC for ground & two upper floors. An affidavit furnished by school dated 13/12/2014 stated basement is lying vacant and now sealed by school. Photographs attached.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

[Handwritten Signature]

[Handwritten Signature]
13/12/15
ADD(BW)