

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/2015/W2/1478

Dated: 14/08/15

FIRE SAFETY CERTIFICATE

Certified that the **Barbeque Nation Restaurant** Located at (A unit of Barbeque Nation Hospitality Ltd.) located at unit no-101&102 first floor A-7 Netaji Subhash Place, Pitampura, New Delhi. was issued FSC vide Letter No. F6/DFS/MS/EH/2012/3671 Dated-05-10-2012. The premises was re inspected by the officers concerned of this department on 04-08-2015 in the presence of Mr. T Ahamad (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 14/08/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/08/15..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer
PH 011-23414250

Copy to:

1. Deputy Health Officer (Civil Line Zone), Public Health Department (NDMC), 16, Rajpur Road, Delhi - 110054.
2. Sh. T Ahamad (Manager) Barbeque Nation Restaurant, 101&102 first floor A-7 Netaji Subhash Place, Pitampura, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Barbeque Nation Restaurant (A unit of Barbeque Nation Hospitality Ltd.) located at unit no-101&102 first floor A-7 Netaji Subhash Place, Pitampura, New Delhi.**
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2012/3671 Dated-05-10-2012.
5. Fire Safety directives Letter No. : nil
6. Date of inspection : 04-08-2015
7. Name of the Inspecting Officer : ADO (WP) & DO/west
8. Name and designation of Officer
from the building side : Sh. T Ahamad (Building Owner)
9. Year of Construction :
10. Applicant's letter No. : Nil dated - 07/07/2015

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	50 mtrs	MR
	• Gate width	05 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided <i>three</i>	MR <i>fl.</i>
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 x 1.5 mtr	1.5 mtr, 1.25 mtr & 2 mtr for restaurant	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	2	Provided	MR
	• Basements	NA	NA	NA
	e. Width Of Corridor	<i>2 x 1.5 mtr</i>	<i>2 x 2 mtr</i>	MR
	f. Door Size		<i>1 x 1.2 mtr</i>	

3.	Compartmentation				
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR	✓
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	MR	
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided	MR	
	<ul style="list-style-type: none"> Water Curtain 	NA	NA	NA	
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided	MR	
4.	Smoke managements System				
	<ul style="list-style-type: none"> Basements 	NA	NA	NA	
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	MR	✓
5.	Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers 	10 nos. each type	10 Provided	MR	
	<ul style="list-style-type: none"> Types 	ABC, CO2	Provided	MR	
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR	
6.	First – Aid Hose Reels				
	<ul style="list-style-type: none"> Total numbers on each floor 	1	Provided	MR	
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR	
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR	
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors 	Smoke/ Heat for restaurant	Provided	MR	
	<ul style="list-style-type: none"> Location of Main Panel 	First floor at Restaurant level	Provided	MR	
		NA	NA	NA	
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	MR	
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR	
	<ul style="list-style-type: none"> Hooters' Location 				
8.	MOEFA	Required	Provided	MR	✓
9.	Public Address System	Not Required	Provided	MR	
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basements 	NA	NA	NA	
	<ul style="list-style-type: none"> Upper Floor 	Required for the restaurant	Provided	MR	
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required for the restaurant	Provided	MR	
11.	Internal Hydrants: common with the mall				
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	Provided	MR	
		1	Provided	MR	
	<ul style="list-style-type: none"> Number of hydrants per floor 	1	Provided	MR	
	<ul style="list-style-type: none"> Hose Box 				
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA	
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA	

an
Common

13.	Pumping Arrangements: Command with Building			
<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2280 LPM	Provided	MR	
	90 mtr	Provided	MR	
	2 electric	Provided	MR	
	180 LPM	Provided	MR	
	90 mtr	Provided	MR	
	2280 LPM Diesel	Provided	MR	
	90 mtr	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	450 lpm	Provided	MR	
	50 m	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	<i>Common</i>			
14.	Captive water Storage for fire fighting: Command with Building			
<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	20,000 litres	Provided	MR	
	<i>an</i>			
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts Command with Building			
<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA	
	NA	NA	NA	
19.	Fire control room			
<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/EH/2012/3671 Dated- 05-10-2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

 Officer

Name Uday Vir Singh
 Designation ADO/W P

Signature of the Inspecting


Name Sh. Sumil Chaudhary
 Designation DO/W

